

93



Date: 25/06/2012

AND WHEREAS, the officers of the Board caused visit, inspection of your area/industry on 07/06/2012 and observed that your pollution control devices are inadequate, and Board officer has collected the Joint Vigilance Samples in the presence of your representative on 07/06/2012 and got it analyzed and the results are exceeding the parameters of pH (4.0) prescribed by the Board.

94
:2:

AND WHEREAS, JVS analysis report have been communicated to you from time to time with request to improve performance of your ETP to bring it within limit but you have not taken any corrective measures to comply with the above non-compliance.

NOW THEREFORE, you are hereby directed to show cause as to why legal action shall not be initiated against you under Water (Prevention & Control of Pollution) Act, 1974. Your reply to this notice, shall reach this office within period of 7 days from the date of receipt of this letter, failing which, it will be presumed that you have no say to offer and therefore appropriate legal action as may deemed fit will be initiated against you, which may please be noted.


(S. R. Deshmukh)
Regional Officer, Kalyan

Copy submitted to:

Sr. Law Officer, (P&L) Division/ Regional Officer (HQ),/I/c. HSM Div., MPC Board, Mumbai- for information.

Copy to:

- 1) Sub-Regional Officer, M.P.C.Board, Kalyan-II.
He is directed to serve the notice to the above industry and keep the follow up and inform compliance after 07 days without fail.
- 2) Master file.

Exhibit - V

95

MAHARASHTRA POLLUTION CONTROL BOARD

Sub Regional Office, Tarapur - I

Tel - [952525] 273314



M.I.D.C. Office Compound,
Near Chitralaya, (Boisar)
Tarapur - 401504.
Taluka - Palghar,
Dist - Thane.



No. / MPCB/ SROTR-I / TB - 1050

Date : 02/07/2012.

To,

The Regional officer,
MPCB, Thane.

Sub.- Compliance of the order dated 30.3.2012 passed by Hon'ble high court of the judicature at Mumbai in writ petition no. 17/2011 filed by Nicholas Almeda v/s state of Maharashtra & others.

- Ref.- 1. Board Letter -BO/P&L DIVN./B-2158, dated- 3.4.2012
2. Your mail dated 10.4.2012
3. This office letter MPCB-SRO-TR-1/TB/B-615, dated 10.4.2012
4. This office letter MPCB/SRO-TR-1/B-682, dated 20.4.2012.
5. MPCB/SRO/TR1/TB-695 dated 25.04.2012.

Sir,

With reference to above vide reference no.-3 field officers from SRO Tarapur I & II were assigned duties for carrying out monitoring work of TEPS-CETP Tarapur for 24 hours composite inlet & outlet of effluent. The analysis report of TEP-CETP monitoring report submitted from month of April 2012 and June 2012 are reproduced as below.

Analysis report of TEPS-CETP for the month of April 2012

Date of sampling	Sampling site	Ph	BOD	COD	SS	TDS
10/04/2012	Inlet	5.2	750.0	2480.0	164.0	6452.0
10/04/2012	Outlet	7.1	550.0	1840.0	286.0	8294.0
11/04/2012	Inlet	5.7	640.0	1960.0	206.0	7052.0
11/04/2012	Outlet	7.0	550.0	1496.0	162.0	7823.0
12/04/2012	Inlet	6.3	1400.0	3360.0	318.0	9677.0
12/04/2012	Outlet	6.7	1020.0	1920.0	282.0	7154.0
13/4/2012	Inlet	8.5	850.0	2192.0	240.0	8014.0
13/4/2012	Outlet	6.8	540.0	1472.0	284.0	7192.0
14/4/2012	Inlet	2.2	900.0	2352.0	220.0	9144.0
14/4/2012	Outlet	6.9	350.0	1296.0	208.0	7367.0
15/4/2012	Inlet	7.1	550.0	1224.0	230.0	4247.0

96

15/4/2012	Outlet*	7.1	410.0	1288.0	214.0	7182.0
16/4/2012	Inlet	6.3	850.0	2336.0	244.0	8924.0
16/4/2012	Outlet	7.1	260.0	560.0	212.0	2664.0
17/04/2012	Inlet	6.6	470.0	1280.0	288.0	5269.0
17/04/2012	Outlet	6.9	490.0	1360.0	176.0	6765.0
18/4/2012	Inlet	3.6	320.0	1440.0	176.0	6125.0
18/4/2012	Outlet	6.8	460.0	1360.0	124.0	6872.0
19/4/2012	Inlet	6.9	675.0	2192.0	90.0	6133.0
19/4/2012	Outlet	7.2	420.0	1360.0	142.0	7092.0
20/4/2012	Inlet	7.3	510.0	1880.0	148.0	5488.0
20/4/2012	Outlet	6.8	170.0	448.0	282.0	2891.0
21/4/2012	Inlet	7.7	800.0	2384.0	210.0	8736.0
21/4/2012	Outlet	7.6	280.0	744	164	4008.0
22/4/2012	Inlet	7.4	420.0	1152	304	7119.0
22/4/2012	Outlet	7.6	375.0	960	188	4816.0
23/4/2012	Inlet	8.8	940.0	2768.0	284.0	7746.0
23/4/2012	Outlet	7.8	330.0	776.0	186.0	2885.0
24/04/2012	Inlet	8.4	750.0	2240.0	222.0	4862.0
24/04/2012	Outlet	7.8	632.0	632.0	162.0	1783.0
25/4/2012	Inlet	7.4	620.0	1552.0	142.0	5094.0
25/4/2012	Outlet	6.8	390.0	1248.0	180.0	6258.0
26/4/2012	Inlet	6.9	2000.0	2880.0	158.0	7649.0
26/4/2012	Outlet	6.9	190.0	640.0	192.0	3275.0
27/4/2012	Inlet	7.6	750.0	1856.0	168.0	5544.0
27/4/2012	Outlet	7.2	430.0	1096.0	208.0	4018.0
28/4/2012	Inlet	7.9	1600.0	2368.0	144.0	8933.0
28/4/2012	Outlet	6.7	725.0	1504.0	122.0	7248.0
29/4/2012	Inlet	6.2	950.0	2752.0	154.0	5162.0
29/4/2012	Outlet	7.4	320.0	1144.0	126.0	4081.0
30/4/2012	Inlet	6.9	700.0	1808.0	184.0	6952.0
30/4/2012	Outlet	7.3	320.0	856.0	212.0	4271.0

97

Analysis report of TEPS-CETP for the month of June- 2012

Date of sampling	Sampling site	Ph	BOD	COD	SS	O & G
07.06.2012	Inlet	7.6	925	2048	382	7
07.06.2012	Outlet	6.9	520	920	120	5.2
08.06.2012	Inlet	7.6	520	4400	186	8.6
08.06.2012	Outlet	7	510	856	114	1.4
09.06.2012	Inlet	6.6	925	2848	414	6.8
09.06.2012	Outlet	7.1	420	1032	170	1.8
10.06.2012	Inlet	5.8	510	2368	320	5.6
10.06.2012	Outlet	7	470	908	146	1
11.06.2012	Inlet	6.2	1300	3640	212	9
11.06.2012	Outlet	6.6	1050	1728	202	4
12.06.2012	Inlet	6.5	1350	2208	212	12
12.06.2012	Outlet	7.1	240	816	166	1.4
13.06.2012	Inlet	7.4	975	2784	378	17
13.06.2012	Outlet	7.1	650	1368	338	BDL
14.06.2012	Inlet	7.5	900	2384	426	3.6
14.06.2012	Outlet	7.2	170	840	212	BDL
15.06.2012	Inlet	3.5	975	2656	358	11
15.06.2012	Outlet	7.3	500	1016	322	9.4

MPCB has prosecuted TEPS CETP at the Ho'nble CJM Court at Thane vide RCC- 388/10 due to non compliance of consented discharge standards. Thereafter TEPS CETP has started their up gradation work. The up gradation work which was planned by TEPS is now at final stage of completion stage. The brief up gradation work carried out by TEPS-CETP is as below.

- (1. Old & partial working diffused Aeration System of aeration tank -1 was replaced with nine numbers of Aspirators in march-2011 & same were at work.
2. Old & partial working diffused Aeration System of Aeration Tank -2 was replaced with nine numbers of Aspirators in july-2011 & same were at work.
3. Old & partial working diffused Aeration System of aeration tank -3 was now replaced with nine numbers of Aspirators. It's start up & commissioning activity was going on. As informed by TEPS it will be commissioned within next 15 days. The cost incurred for above upgradation to aspirators was Rs. 2.93 Crore.
4. TEPS CETP has informed t that the partial broken air grid rectification work of aeration tank -4 will be taken in hand after commissioning of aspirator installation of Aeration Tank-C.)

5. As informed by TEPS vide letter TEPS/MPCB-SRO-T/04-2012/ 21.4.2012 that their one of secondary clarifier's bottom recycle out valve was choked. The same clarifier TEPS isolated for replacement of its said bottom valve. Now entire load diverted to second clarifier. As informed by TEPS the work will be completed within 10 days.

From the above analysis report it is observed that the TEPS CETP is still not achieving the results as the up gradation work is under stabilization stage, an

TEPS CETP is receiving more effluent over & above its capacity. The only alternative is to provide additional CETP. TEPS CETP has received plot from MIDC admeasuring 85000 sq. mtr. The trees have been removed. Tenders has been received & also opened. But the physical progress is very slow.

List of LSI/MSI Industries to whom Voluntary Closure direction are issued from MIDC Tarapur Industrial Area

Sr. No	Name of Industry	Category of Industries (MSI/LSI)	Generation & discharge of effluent m3/day into CETP	Action initiated by the Board against defaulting unit
1	M/s Camlin fine Camicals Plot No: D-2/3 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 20.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1063 dated 12.04.2012
2	M/s Jivraj Camicals (Calayx Chemicals & Pharmaceuticals) Plot No:N-90 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 7.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1074 dated 12.04.2012
3	M/s Aarti Drugs Ltd Plot No:N-198 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 63.10	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1073 dated 12.04.2012
4	M/s Bajaj Health Care Plot No:N-216,217 MIDC Tarapur, Tal: Palghar, Dist: Thane	MSI	Industrial Effluent - 69.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1072 dated 12.04.2014
5	M/s Sarex Overseas Plot No:N-131,132 MIDC Tarapur, Tal: Palghar, Dist: Thane	MSI	Industrial Effluent - 25.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1070 dated 12.04.2012
6	M/s Aarti Drugs Ltd Plot No:E-9/3 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 34.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1068 dated 12.04.2012

7	M/s Aarto Drugs Ltd Plot No: E-1/22 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 70.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1066 dated 12.04.2012
8	M/s Auro Laboratories Plot No: K-56 MIDC Tarapur, Tal: Palghar, Dist: Thane	MSI	Industrial Effluent - 19.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1064 dated 16.05.2012
9	M/s Everest Kantoo Cylinders Plot No: N-62 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 10.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1289 dated 22.06.2012
10	M/s Mudra Life Style Plot No: D-1 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 115.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1142 dated 29.05.2012
11	M/s Resonance Specialities Plot No: T-140 MIDC Tarapur, Tal: Palghar, Dist: Thane	MSI	Industrial Effluent - 11.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1085 dated 18.05.2012

List of SSI Industries to whom Voluntary Closure direction are issued from MIDC Tarapur Industrial Area

Sr. No	Name of Industry	Category of Industries (MSI/LSI)	Generation & discharge of effluent m3/day into CETP	Action initiated by the Board against defaulting unit
1	M/s Trichem Science Ltd Plot No: K-57 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 0.2	Voluntary closure direction issued by MPCB Board - MPCB/ROT/ dated 12.04.2012
2	M/s Mohini Organics Plot No: T-77,78,79 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 1.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1088 dated 12.04.2012
3	M/s Salvi Chemicals Plot No: E-93 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 55.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1067 dated 12.04.2012
4	M/s Genesis Colar Plot No: F-4/22 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 0.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1137 dated 12.04.2012

100

5	M/s Alpha Dychem Plot No N-223 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 5.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1071 dated 12.04.2012
6	M/s Ramdev Chemicals Plot NoE-41 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 2.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1069 dated 12.04.2012
7	M/s Vardhaman Dyestuff Plot No N-34 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 68.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1281 dated 22.06.2012
8	M/s Dhoopchem Pvt. Ltd Plot No T-22/23 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 13.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1288 dated 22.06.2012
9	M/s Laxmi Dyestuff Pvt Ltd Plot No T-22/23 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 25.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/1270 dated 22.06.2012
10	M/s Shree Vinayak Industries Plot No E-1/1 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial effluent - 1.5	Voluntary closure direction issued by MPCB Board - MPCB/ROT/CD/1268 dated 19.06.2012
11	M/s Khanvelkar Plasticizer Plot No T-82 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial effluent -11.0	Voluntary closure direction issued by MPCB Board - MPCB/ROT/CD/1285 dated 22.06.2012

List of LSI/MSI/SSI Industries to whom PD/SC are issued from MIDC Tarapur Industrial Area

Sr. No	Name of Industry	Category of Industries (MSI/LSI SSI)	Generation & discharge of effluent m3/day into CETP	Action initiated by the Board against defaulting unit
1	M/s Calyx Chemicals & Pharmaceuticals Plot No:N-91/102 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 53.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD dated 14.04.2012
2	M/s Aarti Industries Ltd Plot No:L-5 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 20.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD-1082 dated 17.04.2012

3	M/s Aarti Industries Ltd Plot No: K-18/19 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 50.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD- 1080 dated 17.04.2012
4	M/s Crown Chemicals Plot No: E-87/88 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 8.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD- 1083 dated 17.04.2012
5	M/s Pharmaceuticals Products (I) Ltd Plot No: 24/25 MIDC Tarapur, Tal: Palghar, Dist: Thane	MSI	Industrial Effluent - 33.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD- 1081 dated 17.04.2012
6	M/s K.P Chemicals Plot No: L-63 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 11.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD- 1292 dated 22.06.2012
7	M/s Valsad District Co Op Milk Producers Plot No: M-12 MIDC Tarapur, Tal: Palghar, Dist: Thane	LSI	Industrial Effluent - 90.0	Showcause Notice issued by MPCB Board - MPCB/ROT/SCN- 1271 dated 22.06.2012
8	M/s Ravikiran Chemicals Plot No: L-7 MIDC Tarapur, Tal: Palghar, Dist: Thane	SSI	Industrial Effluent - 6.0	Proposed direction issued by MPCB Board - MPCB/ROT/PD- 1076 dated 17- 05.2012

102

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1085

Date: 18/05/2012.

To,
M/s. Resonance Specialities Ltd.,
Plot No.T-140, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 19/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1088

Date: 16/05/2012.

To,
M/s. Mohini Organic Pvt. Ltd.,
Plot No.T-77,78,79, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 19/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)

Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane

5th Floor, Office Complex Bldg.,

Near Mulund Check Naka,

Wagale Estate,

Thane-400 604.

No. MPCB/ROT/ 1063

Date: 16/05/12

To,

M/s. Camlin Fine Chemical,
Plot No.D-2/3, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,

2) Regional Officer (H.O.), MPC Board, Mumbai-22.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in




Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1064

Date: 16/05/2012.

To,
M/s. Auro Laboratories Ltd.,
Plot No.K-56, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

120517FO150



Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane

5th Floor, Office Complex Bldg.,

Near Mulund Check Naka,

Wagale Estate,

Thane-400 604.

No. MPCB/ROT/ 1065

To,
M/s. Trichem Life Science Ltd.,
Plot No.K-57, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Date: 16/05/2012.

12051750177

120522AF267

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane

5th Floor, Office Complex Bldg.,

Near Mulund Check Naka,

Wagale Estate,

Thane-400 604.

No. MPCB/ROT/ 1074 12057750104
To,
M/s. Jivraj Chemical (Calyx chem. & Pharmaceuticals Unit-II)
Plot No.N-90, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Date: 16/05/2012.

Sub:- Voluntary Closure directions under section 33A of the
Water (P & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.2,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)

Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1287

Date: 22/06/2012.

To,
M/s. Vardhaman Dyestuff,
Plot No. N-34, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 08/05/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

1 : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1288

Date: 22/06/2012.

To,
M/s. Dhoop Chem (I) Pvt. Ltd.,
Plot No. T-123,124, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 09/05/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1289

Date: 22/06/2012.

To,
M/s. Everestkanto Cylinder Ltd.,
Plot No. N-62, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 09/05/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

el : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1290

Date: 22/06/2012.

To,
M/s. Laxmi Dyestuff Pvt. Ltd.,
Plot No. T-22/23, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others,
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 10/05/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 25802272
Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>
E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ID/B- 1125

Date: 23/05/2012

To,
M/s. Aarti Industries Ltd.,
(Formerly known as Aarti Drugs Ltd.)
Plot No. L-5, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub: Interim Directions under section 33 A of the Water (P & CP) Act,
1974 and Air (P & CP) Act, 1981.

Ref: 1) Proposed direction No.MPCB/ROT/PD/1082, dtd. 17/04/2012.
2) Personal hearing dtd. 23/05/2012.

This is with reference to the directions issued by MPC Board vide above referred letter to your industry and subsequent personal hearing given to you on 23/05/2012.

During the course of personal hearing you have informed about the steps being taken to comply with various non-compliances mentioned in the Proposed Directions and have also assured to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing:-

- 1) Industry shall operate & maintain their ETP efficiently to achieve the prescribed standards at all the times.
- 2) Industry shall submit Bank Guarantee of Rs. 1 Lac (Rs. one lac) within a week.

In case, you fail to comply with the above interim directions, MPC Board will have no alternative but to issue appropriate final directions to close down your industry by disconnection of Electricity & Water Supply which may please be noted.

(N. H. Shivangi)
I/c. Regional Officer, Thane.

Copy submitted to:-
Member Secretary, MPC Board, Mumbai.

Copy submitted to:-
1) Sr. Law Officer, P&L (Divn), MPC Board, Mumbai.
2) Regional Officer (HQ), MPC Board, Mumbai.

Copy to: Sub Regional Officer, MPCB, Tarapur-I.
- He shall serve these directions on industry and take timely follow-up & submit progress report.

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ID/B- 1187

Date: 23/05/2012

To,
M/s. Aarti Industries Ltd.,
Plot No. K-18/19, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub: Interim Directions under section 33 A of the Water (P & CP) Act, 1974 and Air (P & CP) Act, 1981.

Ref: 1) Proposed direction No. MPCB/ROT/PD/1082, dtd. 17/04/2012.
2) Personal hearing dtd. 23/05/2012.

This is with reference to the directions issued by MPC Board vide above referred letter to your industry and subsequent personal hearing given to you on 23/05/2012.

During the course of personal hearing you have informed about the steps being taken to comply with various non-compliances mentioned in the Proposed Directions and have also assured to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing:-

- 1) Industry shall operate & maintain their ETP efficiently to achieve the prescribed standards at all the times.
- 2) Industry shall submit Bank Guarantee of Rs. 1 Lac (Rs. one lac) within a week.

In case, you fail to comply with the above interim directions, MPC Board will have no alternative but to issue appropriate final directions to close down your industry by disconnection of Electricity & Water Supply which may please be noted.

(N. H. Shivangi)
I/c. Regional Officer, Thane

Copy submitted to:-
Member Secretary, MPC Board, Mumbai.

Copy submitted to:-
1) Sr. Law Officer, P&L (Divn), MPC Board, Mumbai.
2) Regional Officer (HQ), MPC Board, Mumbai.

Copy to: Sub Regional Officer, MPCB, Tarapur-I.
- He shall serve these directions on industry and take timely follow-up & submit progress report.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1285

Date: 22/06/2012.

To,
M/s. Khanvilkar Plasticizer Pvt. Ltd.,
Plot No. T-82, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 10/05/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/SC/ 1291

Date: 22/06/2012

To,
✓ M/s. Valsad District Co-op. Milk Producers
Union Ltd.,
Plot No. M-12, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Show cause notice under the Water (P. & C.P.) Act, 1974.
Ref:- Analysis report submitted by S.R.O. Tarapur-I, on 22/6/2012.

WHEREAS, you are operating your industry in pollution prevention area declared under Water (P. & C.P.) Act, 1974 & Air (P. & C.P.) Act, 1981. AND WHEREAS, Board has granted consent to your industry subject to certain terms & conditions therein. AND WHEREAS, it is obligatory on your part to comply those conditions and provide necessary water & air pollution control devices and operate them continuously and efficiently so as to meet the standards prescribed in the consent at all times. Further it is also obligatory on your part to provide necessary collection, storage treatment & disposal arrangements to the hazardous wastes generated from your activities.

AND WHEREAS, analysis results of JVS of ETP outlet collected during the visit of Board officials to your unit on 10/5/2012, are exceeding the prescribed limits. This shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP thereby hampering its performance.

This amounts to violation of consent conditions and clearly shows your gross negligent attitude towards pollution control.

AND NOW THEREFORE, you are hereby directed to show cause as to why further legal action shall not be initiated against your industry.

Your compliance report, if any, to this notice, shall be submitted to this office within a week of receipt of this Show Cause Notice or else the wheels of the law will be set in motion which please note.

(N.H. Shivangi)

I/c. Regional Officer, Thane.

Copy submitted to:-
The Regional Officer (H.Q.), M.P.C. Board, Mumbai-22.

Copy to:-
Sub-Regional Officer, M.P.C. Board, Tarapur-I – He is requested to serve this notice on the industry & follow up and report.

STAMP

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/PD/ 1292

Date: 22/06/2012

To,

M/s. K.P. Chemicals,
Plot No. L-63, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Proposed directions under section 33A of the Water (P. & C.P.) Act, 1974 & and section 31A of the Air (P. & C.P.) Act, 1981.
Ref:- Analysis results submitted by S.R.O. Tarapur-I, on 22/06/2012.

WHEREAS, you are operating your industry in pollution prevention area declared under Water (P. & C.P.) Act, 1974 & Air (P. & C.P.) Act, 1981. AND WHEREAS, Board has granted consent to your industry subject to certain terms & conditions therein. AND WHEREAS, it is obligatory on your part to comply those conditions and provide necessary water & air pollution control devices and operate them continuously and efficiently so as to meet the standards prescribed in the consent at all times. Further it is also obligatory on your part to provide necessary collection, storage treatment & disposal arrangements for the hazardous waste generated from your activities.

AND WHEREAS, analysis results of JVS collected from ETP outlet during the visit of Board officials to your unit on 10/5/2012, are highly exceeding the prescribed limits. This shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP thereby hampering its performance.

This amounts to violation of consent conditions and clearly shows your gross negligent attitude towards pollution control.

NOW THEREFORE, in the exercise of the powers conferred upon the undersigned by the Board under Section Sec.33A of Water (P&CP) Act, 1974 & under Sec. 31A of Air (P & CP) Act 1981, I hereby issue proposed directions against your industry as follows:-

- Why your unit shall not be directed to close down its activity forthwith?
- Why the competent authorities shall not be directed to disconnect Water/ Electricity supply to your unit?

.....2/-



117
: 2 :

You shall submit your reply/objections to these directions within a period of 7 days from the date of this letter and remain present for hearing on 28/06/2012 at 3.00 pm to this office, failing which, the Board will have no option than to issue appropriate final directions as may deem fit in your case, which may please be noted.


(N.H. Shivangi)
Regional Officer, Thane

Copy submitted to :

- 1) Sr. Law Officer, M.P.C. Board, Sion, Mumbai-22.
- 2) Regional Officer (HQ), MPC Board, Sion, Mumbai-22.

Copy to:-

Sub-Regional Officer, M.P.C. Board, Tarapur-I – He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1073

To,

M/s. Aarti Drugs Ltd.,
Plot No.N-198, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Date: 16/05/2012.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s State of Maharashtra &
others.
2) Member Secretary's letter No.B0/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. B0/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.2,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ / 072

Date: 16/05/2012

To,
M/s. Bajaj Health Care Ltd.,
Plot No.N-216/217, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

122517PTC/116

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2 you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 107 /

To,

M/s. Alfa Dye Chem,
Plot No.N-223, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Date: 16/05/2012.

120577-FTO/118

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BOP&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)

Regional Officer, Thane

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1070

To,

M/s. Sarex Overseas,
Plot No.131, 132, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

Date: 16/05/2012.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BOP&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROTI/1069

Date: 16/05/2012.

To,
M/s. Ramdev Chemicals,
Plot No.E-41, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

120517/70128

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.

(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id : rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1068

Date: 16/05/2012.

To,
M/s. Aarti Industries,
Plot No.E-9/3, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

2051740133

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.1,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1067

Date: 16/05/2012

To,
M/s. Salvi Chemical,
Plot No.E-93, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

- Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1066

Date: 16/05/2012.

To,
M/s. Aarti Industries,
Plot No.E-21/22, MIDC, Tarapur,
Tal. Palghar, Dist.Thane.

120517FF0148

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No.BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P& L Divn/B-2780, dtd.27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 12/04/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.2,00,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22,
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 2402 0781 / 2401 0437

Fax : 2402 4068

Visit us at :

Website : <http://mpcb.mah.nic.in>

E-mail : mpcb@vsnl.net

BY R.P.A.D./FAX/HAND DELIVERY

NO.BD/P&L Divn./B- 3976



Kalpataru Point,
2nd , 3rd & 4th floor,
Opp. Cineplanet,
Near Sion Circle, Sion (E),
Mumbai - 400 022.

Date: 28/06/2012

To
M/s Mudra Lifestyle Ltd.
Plot No. D-1, MIDC Tarapur
Tal. Palghar
Dis: Thane

Sub: Directions under section 33A of the Water(Prevention
& Control of Pollution) Act 1974

Ref:

- 1) Closure directions issued by the Regional Officer, MPCB, Thane vide letter dtd.29/5/2012.
- 2) Letters dtd.20/6/2012 issued to the Executive Engineer (Water Supply), MIDC Tarapur, Tal: Palghar, Dist: Thane/Executive Engineer, MSEDCL, Palghar by the Regional Officer, MPCB, Thane.
- 3) Regional Officer, MPCB, Thane's letter dtd.25/6/2012 alongwith visit report of Sub-Regional Officer, MPCB, Tarapur dtd.25/6/2012.
- 4) Personal hearing extended to you on 26/6/2012.

We refer to the voluntary closure directions issued by the Regional Officer of the Board at Thane vide letter dtd.29/5/2012 for consuming excess water for your manufacturing activities and also generating excess effluent than the consented quantity. We also refer to the letters dtd.20/6/2012 issued to the Executive Engineer(Water Supply), MIDC Tarapur and Executive Engineer, MSEDCL, Palghar by the Regional Officer, MPCB, Thane to disconnect water/electricity supply to your unit. We further refer to the visit report of the Sub-Regional Officer, MPCB, Tarapur-I dtd.25/6/2012 followed by the personal hearing extended to you on 26/6/2012.

During the course of personal hearing, your representative submitted that you have provided fullfledged ETP comprising of primary, secondary & tertiary treatment facilities and sending hazardous waste to MWML Taloja. You have also submitted that you have closed the five bore-wells located in your premises.


Considering the steps taken by you, you are allowed to restart your manufacturing activities subject to the compliance of following conditions.

- a) You shall operate & maintain your ETP round'O clock, so as to achieve the

127

: 2 :

In case of you fail to comply with the above directions, the Board will have no option than to issue appropriate legal action including forfeiture of the Bank Guarantee against you, which please note.



(Milind Mhaiskar)
Member Secretary

Copy to:

- 1) Sr. Law Officer (P&L Div)/ Regional Officer(HQ), MPCB, Mumbai - for information and necessary follow up.
- 2) Regional Officer, MPCB, Thane / Sub-Regional Officer, MPCB, Tarapur-I - for information and necessary action- They shall ensure compliance of the above directions. Regional Officer-Thane is instructed to forfeit the earlier bank guarantee of Rs.1 Lakh submitted by the above unit.
- 3) The Executive Engineer (Water Supply), MIDC Tarapur, Tal: Palghar, Dist: Thane/The Executive Engineer, MSEDCL, Palghar, Dist: Thane- for information and necessary action - They are directed to reconnect electricity/water supply to the above unit.

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 25802272
Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>
E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

128

No. MPCB/ROT/ 1288

Date: 22/06/2012

To,
M/s. Dhoop Chem (I) Pvt. Ltd.,
Plot No. T-123,124, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd 03/4/12
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd 27/4/12


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 09/05/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane

Copy submitted to:-

- 1) Sr Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ 1287

Date: 22/06/2012

To,
M/s. Vardhaman Dyestuff,
Plot No. N-34, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12
3) Member Secretary's letter No. BO/P&L Divn/E-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 09/05/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id : rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

Date: 22/06/2012

No. MPCB/ROT/ 1289

To,
M/s. Everestkanto Cylinder Ltd.,
Plot No. N-62, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

- Sub:- Voluntary Closure directions under section 33A of the Water (P. & C.P.) Act, 1974, as amended.
- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra & others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms & conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis results of treated effluent collected from the final outlet of your ETP on 09/05/2012. On scrutiny of the same, it is noted that the analysis results are exceeding the prescribed standards by more than 100% which clearly shows that you are not operating your ETP properly and are discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee (B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane. He is requested to serve these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagle Estate,
Thane-400 604.

No. MPCB/ROT/ 1270

Date: 22/06/2012.

To,
M/s. Laxmi Dyestuff Pvt. Ltd.,
Plot No. T-22/23, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

- Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12.
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.


WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent.

AND WHEREAS, Sub Regional Officer (S.R.O.), Tarapur-I, has communicated analysis
results of treated effluent collected from the final outlet of your ETP on 10/05/2012. On scrutiny
of the same, it is noted that the analysis results are exceeding the prescribed standards by more
than 100% which clearly shows that you are not operating your ETP properly and are
discharging sub-standard effluent to the CETP, thereby disturbing its performance.

NOW, THEREFORE, in accordance with the Board's letter under reference No.2 you
are hereby directed to voluntarily stop your manufacturing activities and submit Bank Guarantee
(B.G.) of Rs.25,000/-.

Your compliance report in this regard, shall be submitted to this office within 7 days on
receipt of these directions or else further legal action will be initiated which may result in
disconnection of electric & water supply of your unit which please note.


(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P. & L. Divn.), MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve
these directions on the industry & follow up and report within a week.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272
Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>
E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

Date: 29/05/2012.

No. MPCB/ROT/ 1142.
To,
M/s. Mudra Life Style Pvt. Ltd.,
Plot No D-1, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub:- Voluntary Closure directions under section 33A of the
Water (P. & C.P.) Act, 1974, as amended.

Ref:- 1) Order dated 30/03/12 passed by Hon'ble High Court at Mumbai in writ
petition No. 17/2011 (Nicholas Almedia V/s. State of Maharashtra &
others.
2) Member Secretary's letter No. BO/P&L Divn/B-2158, dtd. 03/4/12
3) Member Secretary's letter No. BO/P&L Divn/B-2780, dtd. 27/4/12.
4) Visit of the Board Officials to your unit on 03/5/2012.
5) Report submitted by S.R.O. Tarapur-I, vide letter No. B-887, dtd
21/5/2012.

WHEREAS Hon'ble High Court of Judicature of Mumbai in writ petition No. 17/2011 filed
by Nicholas Almedia V/s. State of Maharashtra & others, is monitoring the performance of CETP
and industries attached to it in the State of Maharashtra. Hon'ble High Court has directed to
initiate proper action against the defaulting highly polluting units and CETP.

AND WHEREAS, Board has granted consent to your unit with certain terms &
conditions. AND WHEREAS, it is obligatory on your part to operate your effluent treatment
plant properly so as to achieve standards prescribed by the Board in its consent

AND WHEREAS, this office has received complaint against your unit regarding excess
consumption of water and excess generation of effluent than the consented quantity. In this
connection, Board officials have visited to your unit on 03/5/2012 and thereafter S.R.O. Tarapur-
I, has submitted above referred report stating that your are consuming excess water for your
manufacturing activities and are also generating excess effluent than the consented quantity.
Due to this, the already overloaded CETP is not in a position to treat the excess effluent. You
are thus hampering the performance of CETP.

AND WHEREAS S.R.O. Tarapur-I has further stated in his report that you have not
disposed of hazardous waste to MWML and have also not submitted Bank Guarantee (B.G.) of
one lac in accordance with the interim directions issued on 24/01/2012

133

: 2 :

NOW, THEREFORE, in accordance with the Board's letter under reference No.2, you are hereby directed to voluntarily stop your manufacturing activities and submit previous B.G of Rs. one lac in addition to Rs. 2 lacs.

Your compliance report in this regard, shall be submitted to this office within 7 days on receipt of these directions or else further legal action will be initiated which may result in disconnection of electric & water supply of your unit which please note



(N.H. Shivangi)
Regional Officer, Thane.

Copy submitted to:-

- 1) Sr. Law Officer (P & L. Divn.) MPC Board, Mumbai-22.
- 2) Regional Officer (H.Q.), MPC Board, Mumbai-22.

Copy to:- Sub Regional Officer, Tarapur-I, MIDC, Tarapur, Dist. Thane- He is requested to serve these directions on the industry & follow up and report within a week.

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272

Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>

E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

Date: 22/06/2012

No. MPCB/ROT/ID/B- 1994

To

M/s. Industrial Carbon,
Village-Chandansar,
Chandansar Road,
Virar (E), Dist. Thane.

Sub: Interim Directions under section 33 A of the Water (P & CP) Act,
1974 and Air (P & CP) Act, 1981.

Ref: 1) Proposed direction No.MPCB/ROT/PD/1230. dtd 11/06/2012
2) Personal hearing dtd. 22/06/2012.

This is with reference to the directions issued by MPC Board vide above referred letter to your industry and subsequent personal hearing given to you on 22/06/2012.

During the course of personal hearing you have informed about the steps being taken to comply with various non-compliances mentioned in the Proposed Directions and have also assured to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing -

- 1) Industry shall provide the Air Pollution Control equipment within three months.
- 2) Industry shall run proposed APC on D.G. set till electric supply is provided by MSEB.
- 3) Industry shall renew the membership of CHWTSDF within 15 days and Hazardous waste shall be disposed off within 15 days.
- 4) Industry shall submit Bank Guarantee of Rs. 50,000/- within 15 days valid upto one year.

In case, you fail to comply with the above interim directions, MPC Board will have no alternative but to issue appropriate final directions to close down your industry by disconnection of Electricity & Water Supply which may please be noted.

(N. H. Shivangi)

I/c. Regional Officer Thane

Copy submitted to -
Member Secretary, MPC Board, Mumbai.

Copy submitted to:-
1) Sr. Law Officer, P&L (Divn), MPC Board, Mumbai.
2) Regional Officer (HQ), MPC Board, Mumbai.

Copy to: Sub Regional Officer, MPCB, Thane - II.
- He shall serve these directions on industry and take timely follow-up & submit progress report.

NOTAR

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272
Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>
E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane
5th Floor, Office Complex Bldg.
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

No. MPCB/ROT/ID/B- 1125

Date: 23/05/2012

To,
M/s. Aarti Industries Ltd.,
(Formerly known as Aarti Drugs Ltd.)
Plot No. L-5, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub: Interim Directions under section 33 A of the Water (P & CP) Act,
1974 and Air (P & CP) Act, 1981.

Ref: 1) Proposed direction No.MPCB/ROT/PD/1082 dtd. 17/04/2012.
2) Personal hearing dtd. 23/05/2012.

This is with reference to the directions issued by MPC Board vide above referred letter to your industry and subsequent personal hearing given to you on 23/05/2012.

During the course of personal hearing you have informed about the steps being taken to comply with various non-compliances mentioned in the Proposed Directions and have also assured to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing:-

- 1) Industry shall operate & maintain their ETP efficiently to achieve the prescribed standards at all the times.
- 2) Industry shall submit Bank Guarantee of Rs. 1 Lac (Rs. one lac) within a week.

In case, you fail to comply with the above interim directions, MPC Board will have no alternative but to issue appropriate final directions to close down your industry by disconnection of Electricity & Water Supply which may please be noted.

(N. H. Shivargi)
I/c. Regional Officer Thane

Copy submitted to:-
Member Secretary, MPC Board, Mumbai.

Copy submitted to:-
1) Sr. Law Officer, P&L (Divn), MPC Board, Mumbai.
2) Regional Officer (HQ), MPC Board, Mumbai.

Copy to: Sub Regional Officer, MPCB, Tarapur-I.
- He shall serve these directions on industry and take timely follow-up & submit progress report.



MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 25802272
Fax : 25805398

Visit us at:

Website : <http://mpcb.gov.in/>
E-mail Id: rothane@mpcb.gov.in



Regional Office, Thane:
5th Floor, Office Complex Eldg.,
Near Mulund Check Naka,
Wagale Estate,
Thane-400 604.

Date 23/05/2012

No. MPCB/ROT/ID/B- 1157

To,
M/s. Aarti Industries Ltd.,
Plot No. K-18/19, MIDC, Tarapur,
Tal. Palghar, Dist. Thane.

Sub: Interim Directions under section 33 A of the Water (P & CP) Act,
1974 and Air (P & CP) Act, 1981.

Ref: 1) Proposed direction No.MPCB/ROT/PD/1082, dtd: 17/04/2012
2) Personal hearing dtd. 23/05/2012.

This is with reference to the directions issued by MPC Board vide above referred letter to your industry and subsequent personal hearing given to you on 23/05/2012.

During the course of personal hearing you have informed about the steps being taken to comply with various non-compliances mentioned in the Proposed Directions and have also assured to take suitable action in time bound manner. Accordingly, following interim directions are issued for immediate compliance, which were also informed to you during the course of hearing:-

- 1) Industry shall operate & maintain their ETP efficiently to achieve the prescribed standards at all the times.
- 2) Industry shall submit Bank Guarantee of Rs. 1 Lac (Rs. one lac) within a week.

In case, you fail to comply with the above interim directions, MPC Board will have no alternative but to issue appropriate final directions to close down your industry by disconnection of Electricity & Water Supply which may please be noted.

(N. H. Shivangi)
I/c. Regional Officer, Thane

Copy submitted to:-
Member Secretary, MPC Board, Mumbai.

Copy submitted to:-
1) Sr. Law Officer, P&L (Divn), MPC Board, Mumbai
2) Regional Officer (HQ), MPC Board, Mumbai.

Copy to: Sub Regional Officer, MPCB, Tarapur-I.
- He shall serve these directions on industry and take timely follow-up & submit progress report.



137



MUMBAI STATE POLLUTION CONTROL BOARD

Kalpahari Point,
2nd, 3rd & 4th floor,
Opp. Cineplanet,
Near Sion Circle, Sion (E),
Mumbai - 400 022.

No. MPCB/RO(HQ)/ Thane /B: 3959
To,
M/s. Calyx Chemicals & Pharmaceuticals Limited,
Plot N-90, MIDC Tarapur
Tal: Palghar Dist: Thane

Date: 29/06/2012

- Sub: Conditional directions to restart manufacturing activities.
- Ref: 1. Writ Petition no: 17/2011, filed by Nicholas Almeda Vs State of Maharashtra & Others.
2. Voluntary Closure issued to the unit vide no: MPCB/ROT/1074 dated: 16/05/2012
3. Your reply & request letter dated: 30/05/2012
4. Compliance report of Regional Officer, Thane vide dated: 25/06/2012
5. Personal hearing extended to you before the Member Secretary of the Board on 26/06/2012

With refer to the directions of voluntary closure issued by Regional Officer, Thane dated 16/05/2012 followed by the compliance report dated 26/06/2012 & your reply dated: 30/05/2012 In this concern, a personal hearing was extended to you on 26/06/2012. During course of the personal hearing, your submission /say was taken on the record.


In view of the steps taken by the you for improvement in the treatment & disposal of effluent, it was decided to allow you to restart manufacturing activities by issuing final directions, The permission to restart is granted subject to the following terms & conditions:

1. You shall operate and maintain existing ETP round'O clock, so as to prevent any sort of pollution in the surrounding area and to bring all the parameters to the prescribed standards within 7days time.
2. You shall upgrade your existing ETP in order to achieve standards prescribed in Consent granted by MPC Board.
3. You shall operate and maintain full-fledged upgraded Effluent Treatment Plant so as to achieve the standards laid down under the provisions of the Environment (Protection) Act, 1986 & Rules made there under.
4. You shall complete and commission the remaining work of upgradation /stabilization

:2:


5. You are directed to furnish an fresh operational irrevocable bank guarantee of Rs.4 Lakhs for ensuring compliance of directions issued/ consent conditions in favour of Regional Officer, MPC Board Thane, within 15 days time from the date of issue of these directions.

In case of failure to comply with the above directions, the Board will have no option than to issue appropriate legal action including forfeiture of bank guarantee against you, which may please be noted.


(Milind Mhaiskar, IAS)
Member Secretary

Copy to:

- 1] Senior Law Officer, MPC Board, Mumbai / Regional Officer (HQ), MPCB, Mumbai- for information & necessary follow-up.
- 2] Regional Officer, MPCB, Thane /Sub-Regional Officer, MPCB, Tarapur-I - They are directed to forfeit existing Bank Guarantee of Rs. 2 Lakhs of M/s. Calyx Chemicals & Pharmaceuticals Limited, Plot N-90, MIDC Tarapur Tal: Palghar Dist: Thane ensure necessary action for compliance of the directions.



Kalpataru Point,
2nd, 3rd & 4th floor,
Opp. Cineplanet,
Near Sion Circle, Sion (E),
Mumbai - 400 022.

Date: 23/06/2012

To,
M/s. Sarex Overseas,
Plot no: 131, 132, MIDC Tarapur
Tal: Palghar Dist: Thane

Ref:

1. Writ Petition no: 17/2011, filed by Nicholas Almeda Vs State of Maharashtra & Others.
2. Voluntary Closure issued to the unit vide no: MPCB/ROT/1070 dated: 16/05/2012
3. Your reply & request letter dated: 07/06/2012
4. Compliance report of Regional Officer, Thane vide dated: 25/06/2012
5. Personal hearing extended to you before the Member Secretary of the Board on 26/06/2012


In view of the steps taken by the you for improvement in the treatment & disposal of effluent, it was decided to allow you to restart manufacturing activities by issuing final directions, The permission to restart is granted subject to the following terms & conditions:

1. You shall operate and maintain existing ETP round 'O' clock, so as to prevent any sort of pollution in the surrounding area and to bring all the parameters to the prescribed standards within 7 days time.
2. You shall upgrade your existing ETP in order to achieve standards prescribed in Consent granted by MPC Board.

140
:2:

4. You are directed to furnish an fresh operational irrevocable bank guarantee of Rs.2 Lakhs for ensuring compliance of directions issued/ consent conditions in favour of Regional Officer, MPC Board Thane, within 15 days time from the date of issue of these directions.

In case of failure to comply with the above directions, the Board will have no option than to issue appropriate legal action including forfeiture of bank guarantee against you, which may please be noted.


(Milind Mhaiskar, IAS)
Member Secretary

Copy to:

- 1] Senior Law Officer, MPC Board, Mumbai / Regional Officer (HQ), MPCB, Mumbai- for information & necessary follow-up.
- 2] Regional Officer, MPCB, Thane /Sub-Regional Officer, MPCB, Tarapur-I - They are directed to forfeit existing Bank Guarantee of Rs. 1 Lakhs of M/s. Sarex Overseas, Plot no: 131, 132, MIDC Tarapur Tal: Palghar Dist: Thane & ensure necessary action for compliance of the directions.

141

MAHARASHTRA POLLUTION CONTROL BOARD

Tel : 2402 0781 / 2401 0437

Fax : 2402 4063

Visit us at :

Website : <http://mpcb.mah.nic.in>

E-mail : mpcb@vsnl.net



Kalpataru Point,
2nd , 3rd & 4th floor,
Opp. Cineplanet,
Near Sion Circle, Sion (E),
Mumbai - 400 022.

No. MPCB/RO(HQ)/ Thane /B: 3741

Date: 19/06/2012

To,
M/s. Bajaj HealthCare Ltd,
Unit N-216, 217, & 128 MIDC Tarapur
Tal: Palghar Dist : Thane

Sub: Conditional directions to restart manufacturing activities.

- Ref: 1. Writ Petition no: 17/2011, filed by Nicholas Almeda Vs State of Maharashtra & Others.
2. Voluntary Closure issued to the unit vide no: MPCB/ROT/1072 dated: 16/05/2012
3. Your reply & request letter dated: 04/06/2012
4. Compliance report of Regional Officer, Thane vide dated: 13/06/2012
5. Personal hearing extended to you before the Member Secretary of the Board on 15/06/2012

With refer to the directions of voluntary closure issued by Regional Officer, Thane dated 16/05/2012 followed by the compliance report dated 13/06/2012 & your reply dated: 04/06/2012. In this concern, a personal hearing was extended to you on 15/06/2012. During course of the personal hearing, your submission /say was taken on the record.

In view of the steps taken by you for upgradation of ETP and your assurance to complete remaining work and commission upgraded ETP by the end of July, 2012, it was decided to allow you to restart manufacturing activities by issuing final directions, The permission to restart is granted subject to the following terms & conditions:

1. You shall operate and maintain existing ETP round'O clock, so as to prevent any sort of pollution in the surrounding area and to bring all the parameters to the prescribed 2012.

2. Completion the remaining work of upgradation by the end of


3. Inlet parameters of GETP and consent granted to the unit



142
:2:

4. You shall operate and maintain full-fledged upgraded Effluent Treatment Plant so as to achieve the standards laid down under the provisions of the Environment (Protection) Act, 1986 & Rules made there under.
5. You are directed to furnish a fresh operational irrevocable bank guarantee of Rs. 50, 000/- for ensuring compliance of directions issued/ consent conditions in favour of Regional Officer, MPC Board Thane, within 15 days time from the date of issue of these directions.

In case of failure to comply with the above directions, the Board will have no option than to issue appropriate legal action including forfeiture of bank guarantee against you, which may please be noted.


(Milind Mhaiskar, IAS)
Member Secretary

Copy to:

- 1] Senior Law Officer, MPC Board, Mumbai / Regional Officer (HQ), MPCB, Mumbai- for information & necessary follow-up.
- 2] Regional Officer, MPCB, Thane /Sub-Regional Officer, MPCB, Tarapur-I - They are directed to forfeit the existing bank guarantee of Rs. 50,000/- out of Rs.1 Lakh of M/s. Bajaj HealthCare Ltd, Unit N-216, 217, & 128 MIDC Tarapur Tal: Palghar Dist: Thane & ensure necessary action for compliance of the directions.

143



MUMBAI CENTRA POLLUTION CONTROL BOARD



Kalpataru Point,
2nd , 3rd & 4th floor,
Opp. Cineplanet,
Near Sion Circle, Sion (E),
Mumbai - 400 022.

No. MPCB/RO(HQ)/ Thane /B: 340]
To,
M/s. Camlin Fine Chemicals,
Plot no: D-2/3, MIDC Tarapur , Tal: Palghar
Dist : Thane.

Date: 30/05/2012

Sub: Conditional directions to restart manufacturing activities.

- Ref:
1. Voluntary Closure issued to the unit vide no: MPCB/ROT/1063 dated: 16/05/2012
 2. Your reply & request letter dated: 21/05/2012
 3. Compliance report of Regional Officer, Thane vide dated: 28/05/2012
 4. Personal hearing extended to you before the Member Secretary of the Board on 29/05/2012~

With refer to the directions of voluntary closure issued by Regional Officer, Thane dated 16/05/2012 followed by the compliance report dated 28/05/2012 & your reply dated: 21/05/2012. In this concern, a personal hearing was extended to you on 29/05/2012. During course of the personal hearing, your submission /say was taken on the record.


Considering the assurance given by you, you are allowed to restart your manufacturing activities. The permission to restart is granted subject to the following terms & conditions:

1. You shall segregate high COD effluent, and upgrade process equipments to meet effluent discharge standards as per MPCB consent within one month period.
2. You shall not discharge sub-standard high COD effluent to CETP, in order not to disturb performance of the CETP.
3. You shall operate and maintain full-fledged upgraded Effluent Treatment Plant so as to achieve the standards laid down under the provisions of the Environment (Protection)

:2:

4. You shall not take trial run of effluent treatment plant without obtaining permission of the MPC Board.
5. You shall complete up gradation work of ETP within one month period from date of receipt of these directions
6. You shall submit additional operational Bank Guarantee of Rs.1,00,000 /- for ensuring compliance of directions issued/ consent conditions in favour of Regional Officer, MPC Board Thane, which shall be valid up to one year to submitted within 15 days from receipt of these directions.

In case of failure to comply with the above directions, the Board will have no option than to issue appropriate legal action including forfeiture of bank guarantee against you, which may please be noted.



(Milind Mhaikar, IAS)
Member Secretary

Copy to:

- 1] Senior Law Officer, MPC Board, Mumbai / Regional Officer (HQ), MPCB, Mumbai- for information & necessary follow-up.
- 2] Regional Officer, MPCB, Thane /Sub-Regional Officer, MPCB, Tarapur-I - He is Directed to serve the directions to above industry and necessary action to ensure compliance.