

1	pH	Between	5.5 to 9.0
2	Temperature	Should not exceed 5 c above the ambient temperature of the receiving body	
3	Oil & Grease	Not to exceed	10 mg/l
4	Suspended Solids	Not to exceed	100 mg/l.
5	B.O.D.	Not to exceed	30 mg/l.
6	C.O.D.	Not to exceed	250 mg/l.
7	Chlorides	Not to exceed	600 mg/l.
8	Sulphates	Not to exceed	1000 mg/l
9	Total Dissolved Solids	Not to exceed	2100 mg/l

(iv) **Trade Effluent Disposal:** The treated trade effluent shall be recycled to the maximum extent & remaining shall be used for gardening in factory premises.

(v) **Sewage Effluent Treatment:** The applicant shall provide comprehensive treatment system as is warranted with reference to influent quality and operate and maintain the same continuously so as to achieve the quality of treated effluent to the following standards.

- (1) Suspended Solids Not to exceed 100 mg/l.
- (2) BOD 3 days 27o C. Not to exceed 100 mg/l.

(vi) **Sewage Effluent Disposal:** The treated domestic effluent shall be soaked in a soak pit, which shall be got cleaned periodically. Overflow, if any, shall be used on land for gardening / plantation only.

(vii) **Non-Hazardous Solid Wastes:**

Sr. No.	Type Of Waste	Quantity	UOM	Treatment	Disposal
--	--	--	--	--	--

(viii) **Other Conditions:** Industry shall monitor effluent quantity regularly.

4. The applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Cess Act, 1977 (to be referred as Cess Act) and amendment Rules, 2003 there under

The daily water consumption for the following categories is as under:

- (i) Domestic purpose ... 1.50 CMD
- (ii) Water gets Polluted & Pollutants are Biodegradable ... 1.00 CMD
- (iii) Water gets Polluted, Pollutants are not Biodegradable & Toxic ... 0.00 CMD
- (iv) Industrial Cooling, spraying in mine pits or boiler feed ... 0.00CMD

The applicant shall regularly submit to the Board the returns of water consumption in the prescribed form and pay the Cess as specified under Section 3 of the said Act.

*(Signature)*  
6/1/14

Sr. No.	Type Of Waste	Quantity	UOM	Disposal
<b>The Industry shall not produce any type of Hazardous waste.</b>				

(ii) Treatment: - NIL

1. The authorization is hereby granted to operate a facility for collection, storage, transport & disposal of hazardous waste.
2. The industry should comply with the Hazardous Waste (M&H) Rules, 2003.

**9. Industry shall comply with following additional conditions:**

- i. The applicant shall maintain good housekeeping and take adequate measures for control of pollution from all sources so as not to cause nuisance to surrounding area / inhabitants.
- ii. The applicant shall bring minimum 33% of the available open land under green coverage/ tree plantation.
- iii. Solid waste - The non hazardous solid waste arising in the factory premises, sweepings, etc., be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal to dumping ground.
- iv. The applicant shall provide for an alternate electric power source sufficient to operate all pollution control facilities installed by he applicant to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms & conditions of this consent regarding pollution levels.
- v. The applicant shall not change or alter quantity, quality, the rate of discharge, temperature or the mode of the effluent / emissions or hazardous wastes or control equipments provided for without previous written permission of the Board.
- vi. The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous wastes to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
- vii. The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent.
- viii. The firm shall submit to this office, the 30<sup>th</sup> day of September every year, the Environmental Statement Report for the financial year ending 31<sup>st</sup> March in the prescribed Form-V as pre the provisions of rule 14 of the Environment (Protection) (Second Amendment) Rules, 1992.
- ix. As inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
- x. The applicant shall install a separate electric meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
- xi. Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes / sewers down- stream of the terminal manholes. No effluent shall find its way other than in designed and provided collection System.