

# MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 24010437/24014701/24020781  
Fax : 24024068/24023516  
Website : <http://mpcb.gov.in>  
E-Mail : [jdair@mpcb.gov.in](mailto:jdair@mpcb.gov.in)



KALPATARU POINT, 3<sup>rd</sup> Floor,  
Sion-Matunga Scheme Rd. No.8,  
Opp. Sion Circle, Sion (East),  
Mumbai-400 022.

RED/LSI

Consent No. BO/JD(APC)/ EIC-NG-7650-12/R/ CC/**(AC-687)**

Date: 04/12/2012

Consent to Operate under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization / Renewal of Authorization under Rule 5 of the Hazardous Wastes (Management Handling & Transboundary Movement) Rules, 2008.[To be referred as Water Act, Air Act and HW (MH & TM) Rules respectively].

CONSENT is hereby granted to

**M/s Pench Hydel Power Station,  
MPPGCL, Totladoh, Tal Ramtek, Dist-Nagpur.**

located in the area declared under the provisions of the Water Act, Air act and Authorization under the provisions of HW(MH&TM) Rules and amendments thereto subject to the provisions of the Act and the Rules and the Orders that may be made further and subject to the following terms and conditions:

1. **The Consent to Operate is granted for a period upto- 31.07.2013.**
2. **The Consent is valid for the manufacture of +**

Sr. No.	Products	Maximum Qty.
1	Electricity Generation (Hydroelectric Power Project)	160 MW (20 Lacs unit/day)

3. **CONDITIONS UNDER WATER ACT :**

- (i) The daily quantity of trade effluent from the factory shall be NIL.
- (x) The daily quantity of sewage effluent from the factory shall not exceed 5.3 m<sup>3</sup>.
- (iii) Trade Effluent Treatment and Disposal:  
**Tail race discharge from the Hydroelectric Power Plant shall be 10.0 MCM/day.**
- (iv) **Sewage Effluent Treatment :** The applicant shall provide comprehensive treatment system as is warranted with reference to influent quality and operate and maintain the system continuously so as to achieve the quality of treated effluent to the following standards.

(1) Suspended Solids	Not to exceed	100	mg/l.
(2) BOD 3 days 27° C	Not to exceed	100	mg/l.
- (xi) **Sewage Effluent Disposal:** The treated domestic effluent shall be used on land for gardening / plantation only.
- (vi) **Non-Hazardous Solid Waste:**

Type of waste	Quantity	Treatment	Disposal
.....	.....	.....	.....
- (vii) **Other conditions :** NIL.

4. The applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Act, 1977 (to be referred as Cess Act) and Rules thereunder:

The daily water consumption for the following categories is as under:

- |                                 |     |      |         |
|---------------------------------|-----|------|---------|
| (i) Domestic                    | ... | 6.5  | CMD     |
| (ii) Industrial Processing      | ... | 10.0 | MCM/day |
| (iii) Industrial Cooling/Boiler | ... | ---  | CMD     |
| (iv) Agriculture/Gardening      | ... | 0.1  | CMD     |

The applicant shall regularly submit to the Board the returns of water consumption in the prescribed form and pay the Cess as specified under Section 3 of the said Act.

5. **CONDITIONS UNDER AIR ACT :**

- (i) The applicant shall install a comprehensive control system consisting of control equipment as is warranted with reference to generation of emission and operate and maintain the system continuously so as to achieve the level of pollutants to the following standards :  
**A) Control Equipment :** Air pollution control equipments of adequate capacity shall be provided to limit the emissions.

**B) Standards for Emissions of Air Pollutants :**

- (i) SPM Not to exceed 150 mg/Nm<sup>3</sup>  
(ii) SO<sub>2</sub> Not to exceed .... kg/day

**C) Conditions for D.G. Set:-**

1] Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically. 2] Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/acoustic treatment of the room should be designed for minimum 25 dB(A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and the average. 3] The industry shall take adequate measures for control of noise levels from its own sources within the premises in respect of noise to less than 55 dB(A) during day time and 45 dB(A) during the night time. Day time is reckoned between 6 a.m. to 10 p.m. and night time is reckoned between 10 p.m. to 6 a.m. 4] Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by providing sitting and control measures. 5] Installation of DG Set must be strictly in compliance with the recommendations of DG Set manufacturer. 6] A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use. 7] D.G. Set shall be operated only in case of power failure. 8] The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.

**(ii) The applicant shall observe the following fuel pattern :-**

<u>Sr.No.</u>	<u>Type of Fuel</u>	<u>Quantity</u>
.....	.....	.....

**(iii) The applicant shall erect the chimney(s) of the following specifications :-**

<u>Sr.No.</u>	<u>Chimney attached to</u>	<u>Height in Mtrs.</u>
.....	.....	.....

- (viii) The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform for monitoring the air emissions and the same shall be open for inspection to/and for use by the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
- (ix) The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB(A) during day time and 70 dB(A) during night time. Day time is reckoned between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.

**(vi) Other Conditions :**

- 1) The industry should not cause any nuisance in surrounding area.
- 2) The industry should monitor stack emissions and ambient air quality regularly.

**6. CONDITIONS UNDER HW (M&H) RULES, 1989 & AMENDMENT RULES :**

(i) The applicant shall handle hazardous wastes as specified below:

Sl. No.	Item No. of process generating HW as per Schedule-I	Type of Waste	Quantity	Disposal
1	5.1	Used/spent oil	Irrespective of any quantity	By sale to MPCB/CPCB authorised recycler/reprocessor
2	5.2	Waste & Residue containing oil		


7. Whenever due to any accident or other unforeseen act or even, such emissions occur or are apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.

**8. General Conditions :**

- (i) The applicant shall maintain good house keeping and take adequate measures for control of pollution from all sources so as not to cause nuisance to surrounding area/inhabitants.
- (ii) The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement by 30<sup>th</sup> September every year on available open land area, number of trees surviving as on 31<sup>st</sup> March of the year and number of trees planted in September end.

- (iii) Solid Waste – The non-hazardous solid waste arising in the factory premises, sweepings, etc. shall be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall obtain necessary permissions from civic authorities for disposal to dumping ground.
  - (iv) The applicant shall provide for an alternate electric power source sufficient to operate all pollution control facilities installed by the applicant to maintain compliance with the terms and conditions of this consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by the terms and conditions of this consent regarding pollution levels.
  - (v) The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or mode of the effluent/emissions or hazardous wastes or control equipments provided for without the previous written permission of the Board.
  - (vi) The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
  - (vii) An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
  - (viii) The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
  - (ix) Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers down stream of the terminal manholes. The effluent shall find its way other than in designed and provided collection system.
  - (x) Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
  - (xi) The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain a clean and safe environment in and around the factory premises.
9. The applicant shall obtain Consent to Operate before Actual Commencement of the production activity.
  10. **The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent**
  11. This Board reserves the right to amend or add any conditions in this consent and the same shall be binding on the Applicant.
  12. **This is issued pursuant to the decision of Consent Appraisal Committee meeting of the Board held on 26<sup>th</sup> November, 2012.**
  13. The total capital investment of industry is Rs.149.53/- Crore

For and on Behalf of the  
Maharashtra Pollution Control Board.

  
(Rajeev Kumar Mittal, IAS)  
Member Secretary

To,  
M/s Pench Hydel Power Station,  
MPPGCL, Totladoh, Tal Ramtek, Dist-Nagpur.

Copy to:

1) Regional Officer, MPCB, Nagpur 2) Sub-Regional Officer, MPCB, Nagpur-I.

They are directed to submit the performance report along with monitoring results within one month period and ensure the compliance of consent conditions.

3) Chief Accounts Officer, MPCB, Mumbai.

Received Consent fee of -

<u>Amount</u>	<u>D.D.No.</u>	<u>Date</u>	<u>Drawn on</u>
Rs.2,99,060/-	098378	23.07.2012	SBI
Rs.100/-	005315	25.07.2011	Bank of India

4] Cess Branch, MPCB.