

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 4010437/4020781
/4037124/4035273
Fax : 24044532/4024068 /4023516
Email : enquiry@mpcb.gov.in
Visit At : <http://mpcb.gov.in>



Kalpataru Point, 3rd & 4th floor, Sion- Matunga
Scheme Road No. 8, Opp. Cine Planet Cinema, Near
Sion Circle, Sion (E),
Mumbai - 400 022

Consent order No :- BO/JD(APC)/ EIC No.CH-1133-12/R/CC/ **CAE-6722**

Date- **08/08/2013**

To,
M/s. Shree Sidhballi Ispat Ltd.,
Plot No. C-2 & 3, MIDC Tadali Growth Center,
Tadali, Tal & Dist - Chandrapur.

Subject: Renewal of Consent - RED category.

Ref : 1. Earlier Consent granted vide no. BO/JD(APC)/ EIC No.CH-0771-12/R/CC- CAC-509 dated 17.07.2012

2. Minutes of CC/CAC meeting held on 5.7.2013.

Your application

Dated:21.12.2012

For: Consent to Renewal under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 5 of the Hazardous Wastes (M, H & T M) Rules 2008 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

The consent is granted for a period from **31.12.2012 to 31.04.2014**.

The actual capital investment of the industry is Rs.231.75 Crs. (As per C.A.Certificate dated 12.12.2012 submitted by industry along with consent application)

The Consent is valid for the manufacture of -

Sr. No.	Products	Maximum Quantity
1	Sponge Iron from Kiln - I, II and III (Finished & Intermediate)	90,000 MT/Year
2	Steel Ingots, Channels, Rounds, Squares, Angles, Bars etc (Finished)	1,00,000 MT/Year
3	Steel Ingots	43,200 MT/Annum
4	Char (By-Product)	13,500 MT/Year
5	Electricity Generation (12.8 MW Coal based TPP & 7.2 MW WHRB)	20 MW

Conditions under Water (P&CP), 1974 Act for discharge of effluent:

Sr. no.	Description	Permitted quantity of discharge (CMD)	Standards to be achieved	Disposal
1.	Trade effluent	139.5	As per Schedule -I	Recycle
2.	Domestic effluent	12.4	As per Schedule -I	land

Conditions under Air (P& CP) Act, 1981 for air emissions:

Sr. no.	Description of stack / source	Number of Stack	Standards to be achieved
1.	Boiler, furnace	07	As per Schedule -II
2.	Process vents/stack	09	As per Schedule -II
3.	DG set	04	As per Schedule -II

Conditions about Non Hazardous Wastes:

Sr. No.	Type of waste	Quantity	Treatment	Disposal
1.	Iron Ore Fines & Coal Rejects	675 MT/Month		By sale /reuse

- 16) Conditions for D.G. Set
- a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
 - b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
 - c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
 - d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
 - e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use
 - f) D.G. Set shall be operated only in case of power failure.
 - g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
 - h) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel
- 17) The industry should not cause any nuisance in surrounding area.
- 18) The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
- 19) The applicant shall maintain good housekeeping.
- 20) The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a yearly statement by 30th September every year on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end.
- 21) The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
- 22) The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
- 23) The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
- 24) The industry shall submit quarterly statement in respect of industries obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
- 25) The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
- 26) The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification dtd. 16.11.2009 as amended.

2.	ESP Dust	675 MT/Month	--	By landfill/ reuse
3.	Bag Filter Dust	160 MT/Month	--	as above
4.	ABC Sludge/Char Fines	33.5 MT/Month	--	as above
5.	Slag	1000 MT/Month	--	as above
6.	APC Dust (SMS)	20 MT/Month	--	as above
7.	Mill Scale	20 MT/Month	--	as above
8.	Tarry residue (Coal tar)	10 MT/Month	--	As above
9.	Fly Ash	5280 MT/Month	--	Shall be sent to cement manufacturer dispose as per Govt. of India guidelines notification vides no. SO 763(E) dated 14.09.1999 and amendment thereto
10.	Bed Ash	1320 MT/Month	--	


Conditions under Hazardous Waste (MH & TM) Rules, 2008 for treatment and disposal of hazardous waste:

Sr. No.	Type Of Waste	Category	Quantity	UOM	Treatment	Disposal
1.	Used/Spent Oil	5.1	0.25	MT/Month		By Sale to authorized re-processor

The Board reserves the right to review, amend, suspend, revoke etc. this consent and the same shall be binding on the industry.

This consent should not be construed as exemption from obtaining necessary NOC/permission from any other Government authorities.

For and on behalf of the
Maharashtra Pollution Control Board


(V.M.Motghare) - 21/12/12
Member Secretary

Received Consent fee of -

Sr. No.	Amount(Rs.)	DD. No.	Date	Drawn On
1	478600	005764	21.12.2012	ICICI Bank

Copy to:

1. Regional Officer and Sub-Regional Officer, MPCB, Chandrapur
They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Mumbai.
3. CC/CAC desk- for record & website updation purposes.

Schedule-I

Terms & conditions for compliance of Water Pollution Control:

1) A] As per your application, you have proposed to install/ provided the Effluent Treatment Plant (ETP) with the design capacity of 137.5 CMD.

B] The Applicant shall operate the effluent treatment plant (ETP) to treat the trade effluent so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.

Sr No.	Parameters	Standards prescribed by Board (If any)
	I. Compulsory Parameters	Limiting concentration in mg/l (except pH)
01	pH	54.5 -9.0
02	Oil & Grease	10
03	BOD (3 days 27oC)	---
04	Total Dissolved Solids	---
05	Bioassay Test	---
	II Additional Parameters	---
06	Mercury	---
07	Arsenic	---
08	Chromium (Hexavalent)	---
09	Lead	---
10	Cyanide	---
11	Phenolics (C6H5OH)	---
12	Sulphide (as S)	---
13	Phosphate(as P)	---
14	Suspended Solids	100
15	COD	250
16	Chloride	--
17	Sulphate	---

The industrial effluent arising from various sections of Power Plant shall be given such treatment either collective or individually as the site condition permits that the final quality of effluent shall have following character standards.

a. Condenser Cooling Water:

1)	pH	Between	6.5 to 8.5
2)	Temperature	Not to Exceed	5°C
3)	Free available Chlorine	Not to Exceed	0.5 mg/l

b. Boiler Blowdown

1)	Suspended Solids	Not to Exceed	100 mg/l
2)	Oil & Grease	Not to Exceed	20 mg/l
3)	Copper	Not to Exceed	1 mg/l
4)	Iron	Not to Exceed	1 mg/l

Cooling Tower Blowdown

1)	Free available Chlorine	Not to exceed	0.5 mg/l
2)	Zinc	Not to Exceed	1 mg/l
3)	Chromium	Not to Exceed	0.2 mg/l
4)	Phosphate	Not to Exceed	5 mg/l

c. D. M. Plant Effluent

1)	pH	Between	5.5 to 9
2)	BOD 3 days 27 Deg. C.	Not to Exceed	30 mg/l
3)	COD	Not to Exceed	250 mg/l
4)	Suspended Solids	Not to Exceed	100 mg/l
5)	Oil & Grease	Not to Exceed	10 mg/l
6)	TDS	Not to Exceed	2100 mg/l

- C) The treated effluent shall be 100% recycled in the process to achieve zero discharge. In no case effluent shall find its way for gardening/outside factory premises.
- 2) A.] As per your consent application, you have provided Septic tank and soak pit.
- B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards/ prescribed under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.
- | | | |
|-------------------------------------|-----|-------|
| (1) Suspended Solids. Not to exceed | 100 | mg/l. |
| (2) BOD 3 days 27oC. Not to exceed | 100 | mg/l. |
- C] The treated sewage shall be soaked in a soak pit, which shall be got cleaned periodically.
- D] In case the treatment system is combined for trade effluent and sewage then the standards and disposal path prescribed at sr. no.1 B & C of schedule I shall be applicable.
- 3) The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or and extension or addition thereto.
- 4) The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
- 5) The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Cess Act, 1977 and as amended, by installing water meters, filing water cess returns in Form-I and other provisions as contained in the said act.

Sr. no.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Industrial Cooling, spraying in mine pits or boiler feed	1018
2.	Domestic purpose	15.5
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	---
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	----

- 6) The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance / CREP guidelines.

Schedule-II

Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have proposed to install/ provided the Air pollution control (APC) system and also proposed to erect / erected following stack (s) and to observe the following fuel pattern-

Sr. No.	Stack Attached To	APC System	Height in Mtrs.	Type of Fuel	Quantity & UoM	S %	SO ₂ Kg/Day
1.	Coal Crusher & Screening Plant (Kiln I, II & III)	Pulse Jet type Bag Filter	16.0	---	---	---	---
2.	Iron Ore Crushing & Handling Plant (Kiln I, II & III)	Pulse Jet type Bag Filter	12.0	---	---	---	---
3.	Rotary Kilns through WHRB (Kiln I & II)	ESP	51.8	Coal	188 Ton/day	0.5	1880
4.	Rotary Kiln through WHRB (Kiln - III)	ESP	52.0	Coal	95 Ton/day	0.5	950
5.	Coolers Discharge Section (Kiln I & II)	Pulse Jet type Bag Filter	12.0	---	---	---	---
6.	Cooler Discharge (Kiln III)	Pulse Jet type Bag Filter	12.0	---	---	---	---
7.	Cooler Discharge Transfer Tower Section (Kiln I, II & III)	Pulse Jet type Bag Filter	12.0	---	---	---	---
8.	Intermediates Bins & Product Separation & Stock House (Kiln I, II & III) & Primary Coal Crusher of Kiln III	Pulse Jet type Bag Filter	21.0	---	---	---	---
9.	Product Load-out Building (Kiln I, II & III)	Pulse Jet type Bag Filter	12.0	---	---	---	---
10.	Induction Furnace (Old)	Scrubber	40.0	Electricity		---	---
11.	Rolling Mill Furnace	---	44.0	Furnace Oil	10 MT/day	4.5	900
12.	Gasifier Unit	---	21.0	Coal	16 MT/day	0.5	160
13.	D. G. Set (750 KVA)	---	5.5*	HSD	0.35 KL/day	1.0	7
14.	D. G. Set (125 KVA)	---	2.3*	HSD	0.06 KL/day	1.0	1.2
15.	D. G. Set (250 KVA)	---	3.2*	HSD	0.12 KL/day	1.0	2.4
16.	CFBC Boiler (75 TPH capacity)	ESP	98.0	Coal	550 Ton/day	0.5	5500
17.	Coal Crusher House	Pulse Jet type Bag Filter	25.0	---	---	---	---
18.	Coal Bunkers	Pulse Jet type Bag Filter	31.0	---	---	---	---
19.	DG Set (1000 KVA)	---	6.5*	HSD	0.5 KL/day	1.0	10

20.	Induction Furnace (New)	Scrubber	24.0	Electricity	---	---	---
-----	-------------------------	----------	------	-------------	-----	-----	-----

2. The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time / Environmental Clearance / CREP guidelines. (Concern section shall mention specific control equipments)

3. The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:


Particulate matter	Not to exceed	100 mg/Nm ³ .
--------------------	---------------	--------------------------

4. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement well before its life come to an end or erection of new pollution control equipment.

5. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).

Schedule-III
Details of Bank Guarantees

Sr. No.	Consent (C to E/O/R)	Amt of BG Imposed	Submission Period	Purpose of BG	Compliance Period	Validity Date
1	R	Fresh BG of Rs.10 Lakh (top up)	15 days	Operation and Maintenance of Pollution Control System so as to achieve the consented standards.	----	31/08/2014
2	R	Extend the existing BG of Rs. 5.0 Lakhs	15 days	Compliance of consent conditions	---	31.08.2014



Schedule-IV

General Conditions:

- 1) The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
- 2) If the MIDC pipeline is broken/ overflowing chamber, in such cases industry shall not discharge their treated effluent into MIDC drain, it shall be sent to CETP by tanker.
- 3) Industry should monitor effluent quality, stack emissions and ambient air quality monthly/quarterly.
- 4) The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
- 5) Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
- 6) The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
- 7) The firm shall submit to this office, the 30th day of September every year , the Environmental Statement Report for the financial year ending 31st March in the prescribed Form-V as per the provisions of rule 14 of the Environment (Protection) (Second Amendment) Rules, 1992.
- 8) The industry shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the HW(MH&TM) Rules 2008, which can be recycled
- 9) /processed/reused/recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc should go for that purpose. in order to reduce load on incineration and landfill site/environment.
- 10) The industry should comply with the Hazardous Waste (M,H & TM) Rules, 2008 and submit the Annual Returns as per Rule 5(6) & 22(2) of Hazarsous Waste (M,H & TM) Rules, 2008 for the preceding year April to March in Form-IV by 30th June of every year.
- 11) An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
- 12) The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent (in case of Renewal of consent).
- 13) Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act,1981 and Environmental Protection Act,1986 and industry specific standard under EP Rules 1986 which are available on MPCB website(www.mpcb.gov.in).
- 14) The industry shall constitute an Environmental cell with qualified staff/personnel/agency to see the day to day compliance of consent condition towards Environment Protection.
- 15) Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
- 16) Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
- 17) The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
- 18) Conditions for D.G. Set
 - a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
 - b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or

for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.

- c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
 - d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
 - e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use
 - f) D.G. Set shall be operated only in case of power failure.
 - g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
 - h) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel
- 19) The industry should not cause any nuisance in surrounding area.
 - 20) The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
 - 21) The applicant shall maintain good housekeeping.
 - 22) The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a statement on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end, with the Environment Statement.
 - 23) The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
 - 24) The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
 - 25) The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
 - 26) The industry shall submit quarterly statement in respect of industries' obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
 - 27) The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
 - 28) The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification dt. 16.11.2009 as amended.

Specific Conditions-

- 1) The industry shall comply with the notification issued by MoEF for utilization of fly ash from coal or lignite based thermal power plants dated 14th September, 1999 and as amended on 3rd November, 2009.
- 2) Industry shall provide dry fly ash handling & collection system and utilize the fly ash as per the fly ash notification of the Govt. of India
- 3) Transportation of coal & fly ash shall be by closed system, Conveyor system wherever possible.
- 4) The applicant shall operate online continuous monitoring system for process stack emission analysis & same shall be directly connected to MPCB website <http://mpcb.gov.in> as well as to the respective Regional Office within 3 months period and operate the same regularly.
- 5) The applicant shall operate continuous automatic ambient air and micrometeorological monitoring station at location indicated by State Board to be set up and operate at its own cost measure SO₂, NO_x and particulate matter. These CAAQMS shall also have necessary provision of networking to the Air Quality Monitoring network of MPCB.

-----0000-----