

# MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 4010437/4020781  
/4037124/4035273  
Fax : 24044532/4024068 /4023516  
Email : enquiry@mpcb.gov.in  
Visit At : <http://mpcb.gov.in>



Kalpataru Point, 3rd & 4th floor, Sion- Matunga  
Scheme Road No. 8, Opp. Cine Planet Cinema, Near  
Sion Circle, Sion (E),  
Mumbai - 400 022

Consent order No :- BO/EIC No.CH-1359-13/CAC-CELL/CC/ (CAC 9205) Date- 3/10/2013

To,  
M/s. Dhariwal Infrastructure Ltd,  
C- 6, 7, 8, Tadali Growth Centre, MIDC Tadali,  
Dist Chandrapur, Pin 442406

Subject: Consent to 1<sup>st</sup> Operate (Phase-I)/RED category.  
Ref : 1. Consent to Establish granted vide no. BO/RO(P&P)/EIC No. CH-0712-09/E/CC-430, dtd. 20.11.2009  
2. Minutes of CAC meeting held on .....

Your application  
Dated: 25.06.2013.

For: Consent to 1<sup>st</sup> Operate (Phase-I)  
under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under  
Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and  
Authorization under Rule 5 of the Hazardous Wastes (M, H & T M) Rules 2008 is  
considered and the consent is hereby granted subject to the following terms and  
conditions and as detailed in the schedule I, II, III & IV annexed to this order:

- The consent is granted for a period from CoU to 31.08.2014.
- The actual capital investment of the industry is Rs. 1852.50 Crs. (As per C.A. Certificate submitted by industry.
- The Consent is valid for the manufacture of-

| Sr. No. | Product / By-Product Name | Maximum Quantity in MTA |
|---------|---------------------------|-------------------------|
|         | Electricity generation    | 300 MW (1 x 300 MW)     |

- Conditions under Water (P&CP), 1974 Act for discharge of effluent:

| Sr. no. | Description       | Permitted quantity of discharge (CMD) | Standards to be achieved | Disposal   |
|---------|-------------------|---------------------------------------|--------------------------|--|
| 1.      | Trade effluent    | 3888                                  | As per Schedule -I       | Out of 3888 CMD, 2500 CMD treated effluent will be utilized for CHP dust suppression, bed ash quenching, ash slurry water make up, silo dust conditioning, water sprinkling on roads etc and balance 1388 CMD effluent will be utilized for horticulture & green belt on 54 Ha of land |
| 2.      | Domestic effluent | 16                                    | As per Schedule -I       | On land for plantation/gardening   |

- Conditions under Air (P& CP) Act, 1981 for air emissions:

| Sr. no. | Description of stack / source | Number of Stack | Standards to be achieved |
|---------|-------------------------------|-----------------|--------------------------|
| 1.      | Boiler No. I                  | 1 no.           | As per Schedule -II      |
| 2.      | DG set (2 nos.)               | 2 nos.          | As per Schedule -II      |

6. Conditions about Non Hazardous Wastes:

| Sr. no. | Type Of Waste | Quantity & UoM | Treatment | Disposal   |
|---------|---------------|----------------|-----------|--|
| 1       | Fly Ash       | 1810 T/D       | .....     | Cement Manufacturer  |
| 2       | Bottom Ash    | 450 T/D        | .....     | Ash Pond System/Backfilling of mines/quarries, manufacturing building blocks, light weight aggregates, road sub-base etc |

Industry should make provisions for Scientific closure of ash pond with soil cover and tree plantation over it.

7. Conditions under Hazardous Waste (MH & TM) Rules, 2008 for treatment and disposal of hazardous waste:

| Sr. No. | Type Of Waste   | Category            | Quantity | UOM  | Treatment | Disposal   |
|---------|---|---------------------|----------|------|-----------|--|
| 1       | Used Oil/Spent Oil  | 5.1                 | 0.06     | MT   | .....     | To be disposed to authorized Used oil Reprocessors |
| 2       | Spent ion exchange resin containing toxic metals & soent catalyst | 34.2                | 0.15     | MT   | .....     | To be disposed to CHWTSDF                          |
| 3       | Chemical sludge oil & grease skimming resid                       | 34.4                | 0.5      | MT   | ....      |  |
| 4       | Discarded empty containers/barrels/liner                          | 33.3                | 10       | Nos. |           |  |
| 5       | Used Batteries  | sch.-II Part B: B-4 | 3        | Nos. | .....     | To be disposed authorised Battery recycler         |

8. The Board reserves the right to review, amend, suspend, revoke etc. this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/permission from any other Government authorities.

For and on behalf of the  
Maharashtra Pollution Control Board

(Rajeev Kumar Mital, IAS)  
Member Secretary

Received Consent fee of -

| Sr. No. | Amount(Rs.) | DD. No. | Date       | Drawn On   |   |
|---------|-------------|---------|------------|------------|---|
| 1       | 370500      | 006702  | 29.05.2013 | ICICI Bank | (Which include Rs. 100/- as consent form download charges |

Copy to:

1. Regional Officer -MPCB, Chandrapur/ Sub-Regional Officer-MPCB, Chandrapur. They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Mumbai.
3. CAC desk- for record & website updation purposes.

**Schedule-I**

**Terms & conditions for compliance of Water Pollution Control:**

1. A] As per your application, you have provided the Effluent Treatment Plant (ETP) with the design capacity of 6000 CMD.

B] The Applicant shall operate the effluent treatment plant (ETP) to treat the trade effluent so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.

| Sr No. | Parameters              | Standards prescribed by Board                      |
|--------|-------------------------|--|
| I.     | Condenser cooling Water | Limiting Concentration in mg/l, except for pH      |
| 01     | pH                      | Between 6.5 to 8.5                                 |
| 02     | Temperature             | Not to exceed 5°C. than that of intake water temp. |
| 03     | Free available chlorine | Not to exceed 0.5 mg/l                             |
| II.    | Boiler Blow Down        |  |
| 01     | Suspended Solids        | Not to exceed 100mg/l                              |
| 02     | Oil & Grease            | Not to exceed 10mg/l                               |
| 03     | Copper (Total)          | Not to exceed 1mg/l                                |
| 04     | Iron (Total)            | Not to exceed 1mg/l                                |
| III.   | Cooling Tower Blow Down |  |
| 1      | Free available chlorine | Not to exceed 0.5mg/l                              |
| 2      | Zinc                    | Not to exceed 1mg/l                                |
| 3      | Chromium (Total)        | Not to exceed 0.2mg/l                              |
| 4      | Phosphate               | Not to exceed 5mg/l                                |
| IV     | D.M. Plant Effluent     |  |
| 1      | pH                      | Between 5.5 to 9                                   |
| 2      | Suspended Solids        | Not to exceed 100mg/l                              |
| 3      | Oil & Grease            | Not to exceed 10mg/l                               |
| 4      | BOD 3 days              | Not to exceed 30mg/l                               |
| 5      | COD                     | Not to exceed 250mg/l                              |
| 5      | TDS                     | Not to exceed 2100mg/l                             |

C) i) Out of 3888 CMD, 2500 CMD treated effluent will be utilized for CHP dust suppression, bed ash quenching, ash slurry water make up, silo dust conditioning, water sprinkling on roads etc and balance 1388 CMD effluent will be utilized for horticulture & green belt on 54 Ha of land

(ii) There shall not be any discharge of effluent outside the factory premises.

1) A.] As per your consent application, you have provided the septic tank soak pit for disposal of domestic effluent. You have also proposed to provide sewage treatment system with the design capacity of 36 CMD

B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards/ prescribed under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.

- |     |                   |               |     |       |
|-----|-------------------|---------------|-----|-------|
| (1) | Suspended Solids. | Not to exceed | 100 | mg/l. |
| (2) | BOD 3 days 27°C.  | Not to exceed | 100 | mg/l. |

C] The treated sewage shall be disposed on land for gardening/irrigation purpose .

OR

The 100% treated sewage shall be recycled/reused for flushing ,fire fighting etc.

- 2) The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or and extension or addition thereto.
- 3) The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
- 4) The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Cess Act, 1977 and as amended, by installing water meters, filing of water cess returns in Form-I and other provisions as contained in the said act.

| Sr. no. | Purpose for water consumed   | Water consumption quantity (CMD) |
|---------|--|----------------------------------|
| 1.      | Industrial Cooling, spraying in mine pits or boiler feed                                       | 235320                           |
| 2.      | Domestic purpose   | 20                               |
| 3.      | Processing whereby water gets polluted & pollutants are easily biodegradable                   | ....                             |
| 4.      | Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic | 2640                             |

- 5) The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance / CREP guidelines.

## Schedule-II

### Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have provided the Air pollution control (APC) system and also erected following stack (s) and to observe the following fuel pattern-

| Sr. No. | Stack Attached To         | APC System            | Height in Mtrs. | Type of Fuel | Quantity & UoM           | S %           | SO <sub>2</sub> Kg/Day |
|---------|---------------------------|-----------------------|-----------------|--------------|--------------------------|---------------|------------------------|
| 1       | Boiler No.1               | ESP                   | 275             | Coal<br>LDO  | 5520 T/D<br>5.57<br>KL/D | 0.45%<br>1.8% | 51T/d                  |
| 2       | D.G.Set No.1<br>(1500KVA) | Acoustic<br>Enclosure | 7.8             | HSD          | 1.14<br>KL/D             | 1%            | 0.02<br>T/d            |
| 3       | D.G.Set No.2<br>(1500KVA) | Acoustic<br>Enclosure | 7.8             | HSD          | 1.14<br>KL/D             | 1%            | 0.02<br>T/d            |

\*D.G. set installed for emergency power supply.

2. The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time / Environmental Clearance / CREP guidelines. (Concern section shall mention specific control equipments)
3. The industry shall provide & Operate adequate APC's to coal handling plant.
4. Industry shall provide concrete roads & mist type sprinklers/dust suppression system in raw material storage & handling area.
5. The coal transfer points should be provided with suction head and adequate APC system.
6. The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

|                    |               |                         |
|--------------------|---------------|-------------------------|
| Particulate matter | Not to exceed | 50 mg/Nm <sup>3</sup> . |
|--------------------|---------------|-------------------------|

7. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement well before its life come to an end or erection of new pollution control equipment.
8. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).

**Schedule-III**  
**Details of Bank Guarantees**

| Code  | Consent conditions  | BG amount<br>In Rs | Time for<br>compliance |
|-------|---|--------------------|------------------------|
| PNC1  | <b>Handling and disposal of flyash</b>  |                    |                        |
| PNC1c | Mitigation of seepages from wet fly ash conveying system  | 1 lakh             | continuous             |
| PNC1d | Scientific operation of ash pond i.e. uniform distribution of wet slurry in the pond so as to have minimum depth of water | 1 lakh             | continuous             |
| PNC1e | Providing arrangement for reuse of 100% seepage water, arising from ash pond, for ash slurry                              | 1 lakh             | continuous             |
| PAO1  | Towards Operation and Maintenance of Air Pollution Control Devices to achieve emission standards.                         | 25 lakhs           | Monthly                |
| PWO1  | Towards Operation & Maintenance of the Effluent Treatment Plant to achieve disposal standards.                            | 5 lakhs            | Monthly                |

## Schedule-IV

### General Conditions:

- 1) The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
- 2) Industry should monitor effluent quality, stack emissions and ambient air quality monthly/quarterly.
- 3) The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
- 4) Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
- 5) The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
- 6) The firm shall submit to this office, the 30th day of September every year , the Environmental Statement Report for the financial year ending 31st March in the prescribed Form-V as per the provisions of rule 14 of the Environment (Protection) (Second Amendment) Rules, 1992.
- 7) The industry shall send used oil to reprocess/re refiners authorized by MPCB & the Hazardous Waste to CHWTSDF Butibori Nagpur as per the provision contain in the HW(MH&TM) Rules 2008.
- 8) The industry should comply with the Hazardous Waste (M,H & TM) Rules, 2008 and submit the Annual Returns as per Rule 5(6) & 22(2) of Hazarsous Waste (M,H & TM) Rules, 2008 for the preceding year April to March in Form-IV by 30<sup>th</sup> June of every year.
- 9) An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
- 10) The applicant shall obtain Consent to Operate from Maharashtra Pollution Control Board before actual commencement of the Unit/ Activity for proposed other units
- 11) The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent.
- 12) Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act,1981 and Environmental Protection Act,1986 and industry specific standard under EP Rules 1986 which are available on MPCB website([www.mpcb.gov.in](http://www.mpcb.gov.in)).
- 13) The industry shall constitute an Environmental cell with qualified staff/personnel/agency to see the day to day compliance of consent condition towards Environment Protection.
- 14) Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
- 15) Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.

- 16) The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
- 17) Conditions for D.G. Set
- a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
  - b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
  - c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
  - d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
  - e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use
  - f) D.G. Set shall be operated only in case of power failure.
  - g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
  - h) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel
- 18) The industry should not cause any nuisance in surrounding area.
- 19) The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
- 20) The applicant shall maintain good housekeeping.
- 21) The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a statement on available open plot area, number of trees surviving as on 31<sup>st</sup> March of the year and number of trees planted by September end, with the Environment Statement.
- 22) The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
- 23) The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
- 24) The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
- 25) The industry shall submit quarterly statement in respect of industries' obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
- 26) The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
- 27) The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification dt. 16.11.2009 as amended.



- 28) The applicant shall comply with the conditions stipulated in Environmental Clearance granted by MoEF/GoM vide No.J-13012/44/2009-IA.II(T), dtd.27.05.11, J-13011/49/2008-IA.II(T), dtd.27.02.09.
- 29) The industry shall comply with the notification issued by MoEF for utilization of fly ash from coal or lignite based thermal power plants dated 14<sup>th</sup> September, 1999 and as amended on 3<sup>rd</sup> November, 2009.
- 30) Industry shall provide dry fly ash handling & collection system and utilize the fly ash as per the fly ash notification of the Govt. of India
- 31) The use of beneficiated coal as per GOI Notification shall be implemented. Transportation of coal shall be carried out through trucks by covering tarpolin properly till the Rly facility from Walgaon to factory site is provided. Fly ash shall be by transported through bunker having closed system, coal carrying conveyor belt shall be covered from all side with provision of water springing/spraying system properly.
- 32) The applicant shall Operate online opacity meter/continuous monitoring system for process stack emission analysis & same shall be directly connected to MPCB website <http://mpcb.gov.in> as well as to the respective Regional Office within 3 months period and operate the same regularly.
- 33) The applicant shall Operate three continuous automatic ambient air and micrometeorological monitoring station at location indicated by MPC Board to be set up and operate at its own cost for measurement of SO<sub>2</sub>, NO<sub>x</sub> and particulate matter. These CAAQMS shall also have necessary provision of networking to the Air Quality Monitoring network of MPCB.
- 34) They shall promote adoption of clean coal and clean power generation technologies.

-----0000-----