

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 4010437/4020781
 /4037124/4035273
 Fax : 24044532/4024068 /4023516
 Email : jdwater@mpcb.gov.in
 Visit At : <http://mpcb.gov.in>



Kalpataru Point, 3rd & 4th floor, Sion-Matunga Scheme Road No. 8, Opp. Cine Planet Cinema, Near Sion Circle, Sion (E), Mumbai - 400 022

Red/SSI

Consent No: Format 1.0/BO/JD(WPC)/EIC No. - PN-23820-14/R/CC-

Date: 02/11/2014

MPCB/15/13962

To,
 M/s. Executive Engineer MIDC Ranjangaon,
 Common Effluent treatment Plant,
 MIDC, Ranjangaon,
 Tal. Shirur, Dist. - Pune.

Subject: Renewal of Consent for Common Effluent Treatment Plant under RED category.

Ref: Earlier consent granted vide no. BO/JDWPC/EIC-PN-15600-12/CO/ MPCB/13/00693, Dtd. 19/01/2013.

Your application: CR1410000209.

Dated: 18.10.2014.

For: Renewal of Consent for CETP under RED category under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 5 of the Hazardous Wastes (M, H & T M) Rules 2008 is considered and the consent is hereby granted subject to the following terms and conditions and as detailed in the schedule I, II, III & IV annexed to this order:

- The consent is granted for a period from 01/07/2014 upto 31/12/2015.
- The actual capital investment of the industry is Rs. 3.01 Crs. (As per the C.A. Certificate submitted by industry)

3. The Consent is valid for -

Sr. No.	Treatment Facility	Maximum Quantity	Unit
1.	Common Effluent Treatment Plant - The daily quantity of industrial effluent to be treated shall not exceed	3	MLD

4. Conditions under Water (P&CP), 1974 Act for discharge of effluent:

Sr. no.	Description	Permitted quantity of discharge	Standards to be achieved	Disposal
1.	Trade effluent Treatment	3.00 MLD	As per Schedule -I	On land for irrigation by adopting HRTS
2.	Domestic effluent	0.6 CMD	As per Schedule -I	On land for irrigation by adopting HRTS

5. Conditions under Air (P& CP) Act, 1981 for air emissions:

Sr. no.	Description of stack / source	Number of Stack	Standards to be achieved
1	D.G Set (125 KVA)	01	As per Schedule -II

6. Conditions about Non Hazardous Wastes:

Sr. no.	Type Of Waste	Quantity & UoM	Treatment	Disposal

7. Conditions under Hazardous Waste (M, H & TM) Rules, 2008 for treatment and disposal of hazardous waste:

Sr. No.	Type Of Waste	Category	Quantity	UOM	Treatment	Disposal
3	Sludge form WWT	34.3	5	Kg/Day	-	CHWTSDF

8. The Board reserves the right to review, amend, suspend, revoke etc. this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/permission from any other Government authorities.
10. This renewal of grant of consent is issued without prejudice to Hon'ble High court order passed or being passed in the Writ Petition No. 17 of 2011 filed by Nicholas Almedia v/s State of Maharashtra & Others.

For and on behalf of the
Maharashtra Pollution Control Board

Dr. Y. B. Sontakke
Joint Director
(Water Pollution Control)

Received Consent fee of -

Sr. No.	Amount	DD. No.	Date	Drawn On
1.	15,000/-	475085	09/10/2014	Syndicate Bank
2.	7,500/-	869086	27/08/2015	Syndicate Bank

Copy to:

1. Regional Officer -Pune and Sub-Regional Officer- Pune II MPCB, They are directed to submit the separate proposal for the existing Bank Guarantees with your remarks to HQ.
2. Chief Accounts Officer, MPCB, Mumbai.
3. EIC desk- for record & website updaticn purposes.

Schedule-I

Terms & conditions for compliance of Water Pollution Control:

- 1) A] As per your application, you have provided Common Effluent Treatment Plant (ETP) with the design capacity of 3.0 MLD.
- B] The Consent is valid for collection, storage and treatment of Industrial and Domestic Effluent conforming to the inlet standards specified hereunder:-

Sr. No.	Parameters	Standards prescribed by Board (If any)
		Limiting Concentration in mg/l, except for pH & Temperature
1.	pH	5.5 to 9.0
2	Temperature	45°C
3	Oil & Grease	20
4	Phenolic Compounds	5.0
5	Ammonical Nitrogen (as N)	50
6	Cyanide (as CN)	2.0
7	Hexavalent Chromium (as Cr ⁺⁶)	2.0
8	Total Chromium (as Cr)	2.0
9	Copper (as Cu)	3.0
10	Lead (as Pb)	1.0
11	Nickel (as Ni)	3.0
12	Zinc (as Zn)	15
13	Arsenic (as As)	0.2
14	Mercury (as Hg)	0.01
15	Cadmium	1.0
16	Selenium (as Se)	0.05
17	Fluoride (as F)	15
18	Boron (as B)	2.0

In case of SSI Unit BOD of Maximum of 800 mg/l and COD of maximum 1800 mg/l will be allowed. In case of other primary and secondary treatment is required.

Note :

- i) These standards apply to the small scale industries i.e. total discharge upto 25 m³.
- ii) All small Scale Units generating effluent quantity more than 25 m³/day and Large & Medium Scale Units irrespective of the quantity of effluent will have to achieve the standards as prescribed in the letter of Consent issued to them individually under the Water (P & CP) Act 1974, Air (P & CP) Act 1981, Hazardous Waste (M&H) Amendment thereto before discharging the effluent into CETP.

C] Treatment and disposal for combined Industrial and Domestic effluent:

Treatment: The CETP authority shall provide comprehensive treatment system consisting of primary / secondary and/or tertiary treatment as is warranted with reference to influent quality and operate and maintain the same continuously so as to achieve the quality of the treated effluent to the following standards:

Sr. No.	Parameters	Standards prescribed by Board (If any)
	I. Compulsory Parameters	Limiting Concentration in mg/l, except for pH
01	pH	5.5 to 9.0
02	Temperature	40° C In any section of the stream within 15 m downstream from the effluent outlet.
03	BOD 3 Days 27 Deg.C	100
04	Suspended Solids	100
05	COD	250
06	Oil & Grease	10
07	Total Residue Chlorine	Nil
08	Ammonical Nitrogen (as N)	Nil
09	T.K.N	Nil
10	Arsenic (as As)	0.2
11	Mercury (as Hg)	Nil
12	Lead (as Pb)	Nil
13	Cadmium (as Cd)	Nil
14	Chromium Total (as Cr)	Nil
15	Copper (as Cu)	Nil
16	Zinc (as Zn)	Nil
17	Selenium (as Se)	Nil
18	Nickel (as Ni)	Nil
19	Boron (as B)	2.0
20	Percent Sodium	60
21	Cyanide (as CN)	0.2
22	Fluoride (as F)	Nil
23	Sulphide (as S)	Nil
24	Sulphate (as SO ₄)	600
25	Phenolic Compound (as C ₆ H ₅ OH)	Nil
26	Hexavalent Chromium (As Cr+6)	0.1
27	Pesticides	Absent
28	Chloride (as Cl)	600
29	Colour	100 Pt-co unit

Note:-

- i) All efforts should be made to remove colour and unpleasant odour as per as possible.
- ii) If the CETP is not able to achieve the outlet parameters, then all the members and the said Society would be individually and jointly responsible and liable for legal actions under the provisions of sections 47 of the Water (Prevention & Control of Pollution) Act, 1974.

D] Disposal: The treated effluent shall be used on land for irrigation using High Rate Transpiration System (HRTS). In no case the treated effluent shall find its way to any water body at any time and/or any location than the prescribed mode of disposal as above.

2) A.] As per your consent application, you have provided Septic Tank for the Domestic effluent.

B] The Applicant shall operate the sewage treatment system to treat the sewage so as to achieve the following standards/ prescribed under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.


(1)	Suspended Solids.	Not to exceed	100	mg/l.
(2)	BOD 3 days 27°C.	Not to exceed	100	mg/l.

C] The treated sewage shall be disposed on land for gardening/irrigation.

3) The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Cess Act, 1977 and as amended, by installing water meters, filing water cess returns in Form-I and other provisions as contained in the said act.

Sr. no.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Industrial Cooling, spraying in mine pits or boiler feed	Nil
2.	Domestic purpose	1.5
3.	Processing whereby water gets polluted & pollutants are easily biodegradable	Nil
4.	Processing whereby water gets polluted & pollutants are not easily biodegradable and are toxic	Nil

4) The Applicant shall provide Specific Water Pollution control system as per the conditions of EP Act, 1986 and rule made there under from time to time/ Environmental Clearance.



Schedule-II

Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have provided the Air pollution control (APC) system and also erected following stack (s) and to observe the following fuel pattern-


Sr. No.	Stack Attached To	APC System	Height in Mtrs.	Type of Fuel	Quantity & UoM	S %	SO ₂ Kg/Hr
1	D.G. Set (125 KVA)	-----	1.5*	HSD	25 Ltr/Hr.	1.0%	0.35

(*Above the roof of the building where D.G set is installed)

2. The Applicant shall provide Specific Air Pollution control equipments as per the conditions of EP Act, 1986 and rule made there under from time to time.
3. The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

Particulate matter	Not to exceed	150mg/Nm ³
--------------------	---------------	-----------------------


4. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement or well before its life come to an end or erection of new pollution control equipment.
5. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).



Schedule-III
Details of Bank Guarantees

Bank Guarantee Proposed:

Sr. No	Consent (C to E/O/R)	BG Guarantee	Submission Period	Consent conditions	Compliance period	Validity
1	C to R	Rs.5.0 Lakhs	15 Days	Operation and Maintenance of CETP	Monthly	30.04.2016
2	C to R	Rs.2.5 Lakhs	15 Days	CETP shall comply to the directions of CPCB for provision of online monitoring system	Immediately	30.04.2016
3	C to R	Rs. 2.5 Lakhs	15 Days	Tertiary or advance treatment facility	30.04.2016	30.04.2016



Schedule-IV

General Conditions:

- 1) The applicant shall provide facility for collection of environmental samples and samples of trade and sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
- 2) Industry should monitor effluent quality, stack emissions and ambient air quality quarterly.
- 3) The applicant shall provide ports in the chimney/(s) and facilities such as ladder, platform etc. for monitoring the air emissions and the same shall be open for inspection to/and for use of the Board's Staff. The chimney(s) vents attached to various sources of emission shall be designated by numbers such as S-1, S-2, etc. and these shall be painted/ displayed to facilitate identification.
- 4) Whenever due to any accident or other unforeseen act or even, such emissions occur or is apprehended to occur in excess of standards laid down, such information shall be forthwith Reported to Board, concerned Police Station, office of Directorate of Health Services, Department of Explosives, Inspectorate of Factories and Local Body. In case of failure of pollution control equipments, the production process connected to it shall be stopped.
- 5) The applicant shall provide an alternate electric power source sufficient to operate all pollution control facilities installed to maintain compliance with the terms and conditions of the consent. In the absence, the applicant shall stop, reduce or otherwise, control production to abide by terms and conditions of this consent.
- 6) The firm shall submit to this office, the 30th day of September every year , the Environmental Statement Report for the financial year ending 31st March in the prescribed Form-V as per the provisions of rule 14 of the Environment (Protection) (Second Amendment) Rules, 1992.
- 7) The industry shall recycle/reprocess/reuse/recover Hazardous Waste as per the provision contain in the HW(MH&TM) Rules 2008, which can be recycled /processed/reused/recovered and only waste which has to be incinerated shall go to incineration and waste which can be used for land filling and cannot be recycled/reprocessed etc should go for that purpose, in order to reduce load on incineration and landfill site/environment.
- 8) The industry should comply with the Hazardous Waste (M,H & TM) Rules, 2008 and submit the Annual Returns as per Rule 5(6) & 22(2) of Hazardous Waste (M,H & TM) Rules, 2008 for the preceding year April to March in Form-IV by 30th June of every year.
- 9) An inspection book shall be opened and made available to the Board's officers during their visit to the applicant.
- 10) **The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent.**
- 11) Industry shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act,1981 and Environmental Protection Act,1986 and industry specific standard under EP Rules 1986 which are available on MPCB website(www.mpcb.gov.in).
- 12) The industry shall constitute an Environmental cell with qualified staff/personnel/agency to see the day to day compliance of consent condition towards Environment Protection.
- 13) Separate drainage system shall be provided for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No effluent shall be admitted in the pipes/sewers downstream of the terminal manholes. No effluent shall find its way other than in designed and provided collection system.
- 14) Neither storm water nor discharge from other premises shall be allowed to mix with the effluents from the factory.
- 15) The applicant shall install a separate meter showing the consumption of energy for operation of domestic and industrial effluent treatment plants and air pollution control system. A register showing consumption of chemicals used for treatment shall be maintained.
- 16) Conditions for D.G. Set
 - a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.

- b) Industry should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
- c) Industry should make efforts to bring down noise level due to DG set, outside industrial premises, within ambient noise requirements by proper siting and control measures.
- d) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
- e) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use
- f) D.G. Set shall be operated only in case of power failure.
- g) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
- h) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel
- 17) The industry should not cause any nuisance in surrounding area.
- 18) The industry shall take adequate measures for control of noise levels from its own sources within the premises so as to maintain ambient air quality standard in respect of noise to less than 75 dB (A) during day time and 70 dB (A) during night time. Day time is reckoned in between 6 a.m. and 10 p.m. and night time is reckoned between 10 p.m. and 6 a.m.
- 19) The applicant shall maintain good housekeeping.
- 20) The applicant shall bring minimum 33% of the available open land under green coverage/ plantation. The applicant shall submit a statement on available open plot area, number of trees surviving as on 31st March of the year and number of trees planted by September end, with the Environment Statement.
- 21) The non-hazardous solid waste arising in the factory premises, sweepings, etc. be disposed of scientifically so as not to cause any nuisance / pollution. The applicant shall take necessary permissions from civic authorities for disposal of solid waste.
- 22) The applicant shall not change or alter the quantity, quality, the rate of discharge, temperature or the mode of the effluent/emissions or hazardous wastes or control equipments provided for without previous written permission of the Board. The industry will not carry out any activity, for which this consent has not been granted/without prior consent of the Board.
- 23) The industry shall ensure that fugitive emissions from the activity are controlled so as to maintain clean and safe environment in and around the factory premises.
- 24) The industry shall submit quarterly statement in respect of industries' obligation towards consent and pollution control compliance's duly supported with documentary evidences (format can be downloaded from MPCB official site).
- 25) The industry shall submit official e-mail address and any change will be duly informed to the MPCB.
- 26) The industry shall achieve the National Ambient Air Quality standards prescribed vide Government of India, Notification dt. 16.11.2009 as amended.
- 27) The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or an extension or addition thereto.
- 28) The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.

-----0000-----