

MAHARASHTRA POLLUTION CONTROL BOARD

Phone : 4010437/4020781
/4037124/4035273
Fax : 24044532/4024068 /4023516
Email : enquiry@mpcb.gov.in
Visit At : <http://mpcb.gov.in>



Kalpataru Point, 3rd & 4th floor, Sion- Matunga
Scheme Road No. 8, Opp. Cine Planet Cinema, Near
Sion Circle, Sion (E),
Mumbai - 400 022

Consent order No :- Format1.0/BO/CAC-cell/EIC-MU -6448-14 /O(part)/CAC-00376
Date- 8/1/2016

To,
Executive Engineer,
Building Construction Division,
Public Works Department (PWD),
ESIS. Hospital Compound, LBS Marg,
Mulund (W), Mumbai-80.

Subject: 1st Consent to Operate (part) for "PWD's Male beggars Home" and amalgamation with existing
Consent to Operate (part) for "Female beggars Home" project in Orange Category.

Ref :

1. Consent to establish granted vide no. BO/RO-Mumbai/RO(P&P)/EIC MU-1308-10/E/CC-206 dated 3.6.2010.
2. Environmental Clearance granted vide no. J-12011/05/2006-IA-III dated 11.9.2006.
3. Consent to Operate (part) granted vide no. BO/CAC-Cell/EIC-MU-5788-14/O(Part)/CAC-5841 dated 20.06.2014 valid upto 31.10.2016
4. Your Application approved in 6th CAC meeting of 2015-2016 held on 27.08.2015

Your application CO1412000225
Dated: 20.11.2014

For: 1st Consent to Operate (part) for "PWD's Male beggars Home" and amalgamation with existing
Consent to Operate (part) for "Female beggars Home" project in Orange Category.
under Section 26 of the Water (Prevention & Control of Pollution) Act, 1974 & under Section 21 of the Air
(Prevention & Control of Pollution) Act, 1981 and Authorization under Rule 5 of the Hazardous Wastes (M,
H & T M) Rules 2008 is considered and the consent is hereby granted subject to the following terms and
conditions and as detailed in the schedule I, II, III & IV annexed to this order:

1. The Consent to Operate (part) is granted for a period up to 31.01.2017
2. The capital investment of the part of project is Rs. 23.25 crs (i.e. Male Beggar home building: 13.5 crs and Female beggars home building: Rs. 9.75 Crs. as per documents/undertaking submitted by PP; whereas total CI of the entire project is Rs. 376.08 crs)
3. The Consent to Operate (part) is valid for PWD's Male and Female Beggar Home building of Public Works Department (PWD) (Executive Engineer, Building Construction Division), CTS No. 469 A, Ramakrishna Chemburkar marg, Chembur, Mumbai on total plot area of 1,13,924.20 sq.m.(as per EC) and BUA of 11,265.29 sq.m. (BUA of 6,594 sq.m. for Male Beggar Home building and BUA of 4,671.29 Sq.m. for Female Beggar Home building) out of total construction BUA of 2,43,131.28 sq.m. as per Consent to Establish.
4. Conditions under Water (P&CP), 1974 Act for discharge of effluent:

Sr. no.	Description	Permitted quantity of discharge (CMD)	Standards to be achieved	Disposal
1.	Trade effluent	NIL	NA	NA
2.	Domestic	83 CMD	As per	Septic tank and soak pit

SRO Mumbai III/I/O/L/85290000 " Public Works Department (PWD)"

effluent	Schedule -I
----------	-------------

5. Conditions under Air (P& CP) Act, 1981 for air emissions:

Sr. no.	Description of stack / source	Number of Stack	Standards to be achieved
1	DG Set (500 KVA)	1	As per Schedule -II

6. Conditions under Municipal Solid Waste (Management and Handling) Rule,2000:


Sr. no.	Type Of Waste	Quantity & UoM	Treatment	Disposal
1	Nil			

7. Conditions under Hazardous Waste (MH & TM) Rules, 2008 for treatment and disposal of hazardous waste:

Sr. No.	Type Of Waste	Category	Quantity	UOM	Treatment	Disposal
	Nil					

8. The Board reserves the right to review, amend, suspend, revoke etc. this consent and the same shall be binding on the industry.
9. This consent should not be construed as exemption from obtaining necessary NOC/permission from any other Government authorities.
10. PP shall submit the affidavit in Board's prescribed format within 15 days regarding the compliance of conditions of EC and C to O.
11. PP shall comply with the conditions stipulated in Environmental Clearance granted vide no. J-12011/05/2006-IA-III dated 11.9.2006.
12. PP shall obtain revalidated Consent to establish from the Board and shall cover separate area details of government buildings and sale buildings and total CI of the project along with requisite consent fees.
13. PP shall submit details of commissioning and operation of STP to treat the entire sewage generated from the project within 15 days from issue of this consent.
14. This consent is having overriding effect over Consent to Operate (part) granted vide no. BO/CAC-Cell/EIC-MU-5788-14/O(Part)/CAC-5841 dated 20.06.2014.

For and on behalf of the
Maharashtra Pollution Control Board


(Dr. P. Anbalagan, IAS)
Member Secretary

Received Consent fee of –

Sr. No.	Amount(Rs.)	DD. No.	Date	Drawn On
1.	50100/-	018961	26.2.2014	HDFC Bank
2.	10417/-	442489	19.6.2014	Canara bank
3.	25,100/-	465958	05.11.2014	Canara Bank
4.	6250/-	368727	05.12.2015	Canara Bank

Copy to:

1. Regional Officer –Mumbai and Sub-Regional Officer-Mumbai-III, MPCB, Mumbai
-- They are directed to ensure the compliance of the consent conditions.
2. Chief Accounts Officer, MPCB, Mumbai.
3. CC/CAC desk- for record & website updation purposes.

Schedule-I

Terms & conditions for compliance of Water Pollution Control:

- 1) A] As per your application, presently you have provided septic tank and soak pit for treatment of domestic effluent till the provision of the STP.

The Applicant shall operate the septic tank and soak pit to treat the sewage so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.

Sr No.	Parameters	Standards prescribed by Board
01	BOD (3 days 27oC)	100
02	Suspended Solids	100

The treated domestic effluent shall be soaked in a soak pit, which shall be got cleaned periodically. Overflow, if any, shall be used on land for gardening / plantation or discharged in to the municipal sewerage system.

- B] PP shall submit details of commissioning and operation of STP to treat the sewage generated from the project within 15 days from issue of this consent. After commissioning of STP, PP shall treat the entire sewage generated from project in the STP and operate the sewage treatment plant (STP) to treat the sewage so as to achieve the following standards prescribed by the Board or under EP Act, 1986 and Rules made there under from time to time, whichever is stringent.

Sr No.	Parameters	Standards prescribed by Board
		Limiting Concentration in mg/l, except for pH
01	BOD (3 days 27oC)	30
02	Suspended Solids	50
03	COD	100
04	Residual Chlorine	1ppm

The treated effluent shall be 60% recycled for secondary purposes such as toilet flushing, air conditioning, firefighting, Agriculture, on land for gardening etc and remaining shall be discharged in to the municipal sewerage system.

- 2) The Board reserves its rights to review plans, specifications or other data relating to plant setup for the treatment of waterworks for the purification thereof & the system for the disposal of sewage or trade effluent or in connection with the grant of any consent conditions. The Applicant shall obtain prior consent of the Board to take steps to establish the unit or establish any treatment and disposal system or and extension or addition thereto.
- 3) The industry shall ensure replacement of pollution control system or its parts after expiry of its expected life as defined by manufacturer so as to ensure the compliance of standards and safety of the operation thereof.
- 4) The Applicant shall comply with the provisions of the Water (Prevention & Control of Pollution) Cess Act, 1977 and as amended, by installing water meters, filing water cess returns in Form-I and other provisions as contained in the said act.

Sr. no.	Purpose for water consumed	Water consumption quantity (CMD)
1.	Domestic purpose	107

Schedule-II

Terms & conditions for compliance of Air Pollution Control:

1. As per your application, you have installed Air pollution control (APC) system and also erected following stack (s) and to observe the following fuel pattern-


Sr. No.	Stack Attached To	APC System	Height in Mtrs.	Type of Fuel	Quantity & UoM	S %	SO ₂ Kg/Day
1.	DG Set (500 KVA)	Acoustic enclosure	4.5 *	HSD		1	

* above the roof of the building in which it is installed.

2. The applicant shall operate and maintain above mentioned air pollution control system, so as to achieve the level of pollutants to the following standards:

Particulate matter	Not to exceed	150 mg/Nm ³ .
--------------------	---------------	--------------------------

3. The Applicant shall obtain necessary prior permission for providing additional control equipment with necessary specifications and operation thereof or alteration or replacement alteration well before its life come to an end or erection of new pollution control equipment.
4. The Board reserves its rights to vary all or any of the condition in the consent, if due to any technological improvement or otherwise such variation (including the change of any control equipment, other in whole or in part is necessary).



Schedule-III
Details of Bank Guarantees

Proposed BG:

Sr. No.	Consent	Amt of BG Imposed	Submission Period**	Purpose of BG #	Compliance Period	Validity++
1.	C to O (part)	Rs. 10 lakh	15 days from date of issue of consent	Towards compliance of consent conditions	Continuous	Validity of this consent + 4 months

** The above Bank Guarantee(s) shall be submitted by the applicant in favour of Regional Officer at the respective Regional Office within 15 days of the date of issue of Consent.

++ The Bank Guarantee(s) shall be valid for a period upto: Validity of consent + 4 months

Existing BG obtained for above purpose if any may be extended for period of validity as above.

128
20/11/2017

Maharashtra Pollution Control Board

Schedule-IV

General Conditions:

- 1) The applicant shall provide facility for collection of samples of sewage effluents, air emissions and hazardous waste to the Board staff at the terminal or designated points and shall pay to the Board for the services rendered in this behalf.
- 2) The firm shall strictly comply with the Water (P&CP) Act, 1974, Air (P&CP) Act, 1981 and environmental protection Act 1986 and Municipal Solid Waste (Management & Handling) Rule 2000 and E-Waste (Management & Handling) Rule 2011.
- 3) Drainage system shall be provided for collection of sewage effluents. Terminal manholes shall be provided at the end of the collection system with arrangement for measuring the flow. No sewage shall be admitted in the pipes/sewers downstream of the terminal manholes. No sewage shall find its way other than in designed and provided collection system.
- 4) Vehicles hired for bringing construction material to the site should be in good condition and should conform to applicable air and noise emission standards and should be operated only during non-peak hours.
- 5) Conditions for D.G. Set
 - a) Noise from the D.G. Set should be controlled by providing an acoustic enclosure or by treating the room acoustically.
 - b) Applicant should provide acoustic enclosure for control of noise. The acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standards, whichever is on higher side. A suitable exhaust muffler with insertion loss of 25 dB (A) shall also be provided. The measurement of insertion loss will be done at different points at 0.5 meters from acoustic enclosure/room and then average.
 - c) Applicant shall take adequate measures for control of noise levels from its own sources within the premises in respect of noise to less than 55 dB(A) during day time and 45 dB(A) during the night time. Day time is reckoned between 6 a.m. to 10 p.m and night time is reckoned between 10 p.m to 6 a.m.
 - d) Applicant should make efforts to bring down noise level due to DG set, outside their premises, within ambient noise requirements by proper siting and control measures.
 - e) Installation of DG Set must be strictly in compliance with recommendations of DG Set manufacturer.
 - f) A proper routine and preventive maintenance procedure for DG set should be set and followed in consultation with the DG manufacturer which would help to prevent noise levels of DG set from deteriorating with use.
 - g) D.G. Set shall be operated only in case of power failure.
 - h) The applicant should not cause any nuisance in the surrounding area due to operation of D.G. Set.
 - i) The applicant shall comply with the notification of MoEF dated 17.05.2002 regarding noise limit for generator sets run with diesel.
- 6) Solid Waste – The applicant shall provide onsite municipal solid waste processing system & shall comply with Municipal Solid Waste (Management & Handling) Rule 2000 & E-Waste (M & H) Rule 2011.
- 7) Affidavit undertaking in respect of no change in the status of consent conditions and compliance of the consent conditions the draft can be downloaded from the official web site of the MPCB.
- 8) Applicant shall submit official e-mail address and any change will be duly informed to the MPCB.
- 9) The treated sewage shall be disinfected using suitable disinfection method.
- 10) The firm shall submit to this office, the 30th day of September every year, the environment statement report for the financial year ending 31st march in the prescribed Form-V as per the provision of rule 14 of the Environmental (Protection) Second Amended rule 1992.
- 11) **The applicant shall make an application for renewal of the consent at least 60 days before the date of the expiry of the consent.**

-----0000-----

