



महाराष्ट्र प्रदूषण नियंत्रण मंडळ
MAHARASHTRA POLLUTION CONTROL BOARD

कल्पतरू पॉइंट, २, ३ आणि ४ था मजला, मूव्हीमॅक्स सिनेमा समोर,
बीव सर्कल जवळ, बीव (पु), मुंबई - ४०० ०२२

Kalpataru Point, 2nd, 3rd and 4th floor, Opp. MovieMax Cinema,
Near Sion Circle, Sion (E), Mumbai - 400 022



Life
Lifestyle for
Environment



दूरध्वनी / Tel: 022-67808888

ईमेल / Email: eic@mpcb.gov.in

संकेतस्थळ / Website: www.mpcb.gov.in

Ref. No. 1/2401176/2026

Date: 03/08/2026

Notice

Sub: Invitation of Sealed Quotations for Supply, Installation, Testing & Commissioning of One (01 No.) 10 KVA Online UPS System.

With reference to the above subject, Board is inviting Sealed quotations from eligible, experienced and authorised Vendors for Supply, Installation, and Commissioning of One (01 No.) 10 KVA Online UPS System complete with Battery Bank and all necessary accessories for the Sub-Regional Office, Pune-1, Baramati, Pune. The detailed technical specifications, terms and conditions are enclosed as Annexure-I and Annexure-II.

Interested Vendor shall submit their sealed quotations in an envelope superscribed: "Quotation for Supply, Installation, & Commissioning of 10 KVA Online UPS System alongwith Batteries with 1 hour backup"

The quotation shall reach at EIC, Dept., Maharashtra Pollution Control Board, Kalptaru Point 4th Floor, Sion (E) Mumbai- 400 022 within 7 days from issuance of this notice.

The Board reserves the right to accept or reject any or all quotations without assigning any reason thereof.

Place: Mumbai.

Date:


(B. R. Jagtap)
Executive Engineer

Digitally signed by
Bhalachandra Ramdas Jagtap
Date: 03-08-2026 13:12:42

Annexure-I Technical Specifications

1. UPS Rating

- Capacity: 10 KVA.
- Technology: True Online Double Conversion
- Input Voltage: 220/230/240V.
- Output Voltage: 220/230/240V.
- Input Frequency: 45-65Hz $\pm 10\%$
- Output Frequency: 50 Hz
- Efficiency: Minimum 95% in Online Mode.
- Short Circuit Current – 137A
- Communication port – 1n USB port + 1 RS232 Serial port.
- Operating Temperature – 0 to 40 °C
- Noise- Below 55db.
- LCD Display for input/output parameters, battery status, alarms and load.

2. Battery Bank

- Maintenance Free Sealed Lead Acid (SMF VRLA) Batteries.
- Battery backup: Minimum 60 minutes at full load.
- Battery rack with all accessories.
- Interconnecting cables and battery connectors.

3. Protection Features

- Input surge protection
- Output short circuit protection
- Overload protection
- Over temperature protection
- Battery deep discharge protection.
- Automatic battery charging
- Automatic restart after power restoration.

4. Accessories

- Battery Rack
- Input and Output Cables
- Earthing Kit
- Installation materials
- User Manual
- Necessary hardware and accessories for complete installation.

5. Installation

The bidder shall be responsible for:

- Delivery
- Installation
- Testing
- Commissioning
- Demonstration
- Training of users

No additional payment shall be made for installation or commissioning.

6. Warranty

- UPS: Minimum 2 Years Comprehensive On-site Warranty
- Batteries: Minimum 2 Years Warranty
- Free preventive maintenance visits during warranty period.

Annexure-II Terms & Conditions

1. The Vendor should have experience for supply, installation and commissioning of the UPS system.
2. Delivery shall be done at SRO, Pune-1, Office No.4, 3rd Floor Bhigavan Road Baramati, Pune - 413102 within 15 days from the date of issue of Purchase Order.
3. Payment shall be released after successful delivery, installation, testing, commissioning and submission of invoice along with all supporting documents.
4. The quoted price shall be inclusive of packing, forwarding, transportation, installation and commissioning.
5. GST shall be indicated separately.
6. The equipment supplied shall be brand new and unused.
7. The bidder shall provide technical brochures and complete specifications.
8. Any manufacturing defects noticed during the warranty period shall be rectified/replaced without additional cost.
9. The quotation shall remain valid for 90 days from the date of opening.
10. The Board reserves the right to accept or reject any or all quotations without assigning any reason.

Documents to be submitted

1. Quotation on the bidder's letterhead with duly signed by Authorized person.
2. GST Registration Certificate/PAN Card.
3. Experience details of similar supply (Work/Purchase Order should be submitted).
4. Compliance statement against technical specifications.