



RFP for Selection of Service Provider for Supply, installation, and Commissioning the Uninterrupted Power Supply for all Board Offices. (Tender ID: 2022_MPCB_800309_1)
Minutes of Meeting of Pre-bid Conference held on 31 May 2022 and MPCB response to the Queries from Prospective bidder


Sr. No.	RFP Page No	RFP Clause No	Description in RFP	Clarification Sought	MPCB Comments
1	32	Technical Compliance - Pointer 1	Battery Make HBL/ Exide OR Equivalent	Can we put forward any other / Better Battery Make	It is decided to provide major brands of batteries i.e., HBL/ Exide.
2	33	Technical Compliance - Last Point	Software Compatibility Ups should have compatibility with DCIM software	Can we provide any other Software	Suggested: VCOM or Equivalent DCIM
3	19	Bidder Eligibility Criteria - 15.5.4.6	The products must be delivered within 45 (forty-five) days from the date of Purchase order	Can we get a period of 90 days as all deliveries are delayed due to COVID impact	It is decided to provide 60 days for delivery and 60 days for completion of installation. Total 120 days.
4	20	Payment Terms	1 - Against Delivery of UPS at all Locations 75% 2 - Completion of Installation with CoOP. 15% 3 - 30 Days after Issue of CoOP 10%	Can you please change the payment terms to:	It is decided to make the changes in payment terms as below 1) Against Delivery of UPS at all Location - 75% 2) Completion of Installation with CoOP - 25%
5	30	27.3	List of Locations the UPS to be supply, and Electrical Points.	Can we propose lower sizing according to the survey?	Minimum mentioned size in Tender or higher must be supplied
6	32	28 ANNEXURE – 2 - 28.1.5.4	Provide Battery warranty for next 3 (Three) years from the date of completion of installation	Can we propose a one-year warranty with the option to extend it later because OEM does not offer a three-year warranty?	No Change – To comply as per Tender Document
7	NA	NA	EMD & Tender Cost 1. EMD Rs. 2,00,000.00 2. Tender Cost Rs.5,000.00	We are registered in under MSME (Micro, Small & Medium Enterprises), can we get exemption for EMD/Tender Fee against valid certificate	Not Accepted
8	NA	NA	Isolation Transformer not clear in the tender	Must Inbuilt True Galvanic Isolation Transformer have required. External not acceptable – please clear	Bidder can carry out survey and accordingly provide as per their findings.


RFP for Selection of Service Provider for Supply, installation, and Commissioning the Uninterrupted Power Supply for all Board Offices. (Tender ID: 2022_MPCB_800309_1)
 Minutes of Meeting of Pre-bid Conference held on 31 May 2022 and MPCB response to the Queries from Prospective bidder


Sr. No.	RFP Page No	RFP Clause No	Description in RFP	Clarification Sought	MPCB Comments
9	NA	NA	Warranty	Please clear UPS warranty	UPS Warranty is already mentioned in clause no 28.1.5.1 of RFP
10	NA	NA	Last date of submission 06/06/2022	We request you to please extend date till 17/06/2022	Not Accepted


EE


RO-BMW


SO


J.r.c


PMC